DICOM Conformance Statement

Philips IntelliSpace Portal V5.0





Issued by:

Philips Medical Systems Nederland BV, a Philips Healthcare company,

P.O. Box 10.000 5680 DA Best The Netherlands

Email: dicom@philips.com

Internet: http://www.healthcare.philips.com/connectivity

Document Number: PIIOffc.0000142
Date: 06-September-2013

1. DICOM Conformance Statement Overview

This Conformance Statement refers to the Philips IntelliSpace Portal, Philips user environment for multi-modality visualization for CT, MR and NM. All Philips IntelliSpace Portal users enjoy the same easy to use interface and access to advanced applications. This version of the DICOM Conformance Statement applies to Philips IntelliSpace Portal, version 5.0.

The Philips IntelliSpace Portal provides the following DICOM data exchange features:

- It receives images sent from remote systems (e.g. workstations or imaging modalities) and stores them in a database.
- It allows the operator to copy images from the database to remote databases and vice versa. For this purpose the operator is able to query remote databases.

Document Number: PIIOffc.0000142

- It allows the operator to print images (Grayscale and Color) stored in the database on a DICOM printer.
- It is able to read and write DICOM media CD, CD-RW disks.
- It is able to read and write DICOM media DVD+/-R, DVD+/-RW, DVD-RAM disks.




Figure 1: Philips IntelliSpace Portal in a DICOM Network.

The following table presents an overview of all network services and the applicable SOP Classes as provided by the Philips IntelliSpace Portal, where the first column specifies the used SOP Classes as named in PS 3.6 (Ref PS 3.2 Annex A) of the current DICOM Standard. The following table presents an overview of all network services and the applicable SOP Classes as provided by the Philips IntelliSpace Portal, where the first column specifies the used SOP Classes as named in PS 3.6 (Ref PS 3.2 Annex A) of the current DICOM Standard.

Table 1: Network Services

SOP Class		User of	Provider
Name	UID	Service (SCU)	of Service (SCP)
	Other		
Verification SOP Class	1.2.840.10008.1.1	Yes	Yes
Print N	lanagement		
Basic Color Print Management Meta SOP Class	1.2.840.10008.5.1.1.18	Yes	No
>Basic Film Session SOP Class	1.2.840.10008.5.1.1.1	Yes	No
Basic Grayscale Print Management Meta SOP Class	1.2.840.10008.5.1.1.9	Yes	No
>Basic Film Session SOP Class	1.2.840.10008.5.1.1.1	Yes	No
Quer	y/Retrieve		
Study Root QR Information Model - FIND SOP Class	1.2.840.10008.5.1.4.1.2.2.1	Yes	Yes
Study Root QR Information Model - MOVE SOP Class	1.2.840.10008.5.1.4.1.2.2.2	Yes	Yes
•	ransfer		
Computed Radiography Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.1	Yes	Yes
Digital X-Ray Image Storage - For Pres. SOP	1.2.840.10008.5.1.4.1.1.1	Yes	Yes
Digital X-Ray Image Storage - For Proc. SOP	1.2.840.10008.5.1.4.1.1.1.1	Yes	Yes
Digital Mammography X-Ray Image Storage - Pres. SOP	1.2.840.10008.5.1.4.1.1.1.2	Yes	Yes
Digital Mammography X-Ray Image Storage - Proc. SOP	1.2.840.10008.5.1.4.1.1.1.2.1	Yes	Yes
Digital Intra-oral X-Ray Image Storage - Pres. SOP	1.2.840.10008.5.1.4.1.1.1.3	Yes	Yes
Digital Intra-oral X-Ray Image Storage - Proc. SOP	1.2.840.10008.5.1.4.1.1.3.1	Yes	Yes
Encapsulated PDF Storage	1.2.840.10008.5.1.4.1.1.104.1	Yes	Yes
Grayscale Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.1	Yes	Yes
Color Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.2	Yes	Yes
Pseudo-Color Softcopy Presentation State Storage	1.2.840.10008.5.1.4.1.1.11.3	Yes	Yes
Blending Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.4	Yes	Yes
X-Ray Angiographic Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.12.1	Yes	Yes
X-Ray Radiofluoroscopic Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.12.2	Yes	Yes
Positron Emission Tomography Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.128	Yes	Yes
CT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.2	Yes	Yes
Enhanced CT Image Storage SOP Class*	1.2.840.10008.5.1.4.1.1.2.1	No	Yes
Nuclear Medicine Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.20	Yes	Yes
MR Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.4	Yes	Yes
RT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.1	Yes	Yes
RT Dose Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.2	Yes	Yes
RT Structure Set Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.3	Yes	Yes
RT Plan Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.5	Yes	Yes
Raw Data Storage SOP Class	1.2.840.10008.5.1.4.1.1.66	Yes	Yes
Spatial Registration Storage	1.2.840.10008.5.1.4.1.1.66.1	Yes	Yes
Real World Value Mapping Storage	1.2.840.10008.5.1.4.1.1.67	Yes	Yes
Secondary Capture Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.67	Yes	Yes
Multi-frame Single Bit Secondary Capture Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.7.1		
· · · · · · · · · · · · · · · · · · ·	1.2.840.10008.5.1.4.1.1.7.1	Yes	Yes
Multi-frame Grayscale Byte SC Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.7.2	Yes Yes	Yes
Multi-frame Grayscale Word SC Image Storage SOP Class			Yes
Multi-frame True Color Secondary Capture Image Storage	1.2.840.10008.5.1.4.1.1.7.4	Yes	Yes
Key Object Selection Document	1.2.840.10008.5.1.4.1.1.88.59	Yes	Yes
General ECG Waveform Storage SOP Class Philips Private ViewForum 3D Volume New Storage	1.2.840.10008.5.1.4.1.1.9.1.2 1.3.46.670589.5.0.1.1	Yes Yes	Yes Yes

SOP Class			Provider
Name	UID	Service (SCU)	of Service (SCP)
Workflow Management			
Modality Worklist Information Model - FIND SOP Class	1.2.840.10008.5.1.4.31	Yes	No
Storage Commitment Push Model SOP Class	1.2.840.10008.1.20.1	Yes	No

Notes:

- Normally the system (SCU) requests only supported DICOM objects. All SOP Classes support as default Transfer Syntaxes ILE.
 All transfer Syntaxes are configurable in LAN Config.
 - Not supported is JPEG transfer syntax for all SOP classes if the IODs have no pixel data and for all non-storage SOP classes. For media the Philips IntelliSpace Portal supports:
 - FSC service for CD-R, CD-RW, DVD + R, DVD R, DVD + RW, DVD RW, DVD-RAM media
 - FSR service for CD-R, CD-RW, DVD + R, DVD R, DVD + RW, DVD RW, DVD-RAM media
- * Enhanced CT Images (1.2.840.10008.5.1.4.1.1.2.1) will be converted to Classic CT images (1.2.840.10008.5.1.4.1.1.2) upon arrival in Portal.
- Philips IntelliSpace Portal V5.0 does not support CT Images having different x and y values for the DICOM Pixel spacing (0028,0030). Such data sets are blocked from launching into applications.

After data is written to DVD, the DVD is finalized; the finalized DVD can now be read on mostly every DVD reader. All the supported Media Services by Philips IntelliSpace Portal are shown in the next table.

Table 2: Media Services

Media Storage Application Profile	File-set Creator (FSC)	File-set Updater (FSU)	File-set Reader (FSR)
Compact Disk-Recordable			
CT/MR Studies on CD-R	Yes	No	Yes
General Purpose CD-R Interchange	Yes	No	Yes
DVD			
CT/MR Studies on DVD Media	Yes	No	Yes
General Purpose DVD Interchange with JPEG	Yes	No	Yes

2. Table of Contents

	DICOM CONFORMANCE STATEMENT OVERVIEW	
2.	TABLE OF CONTENTS	7
3.	INTRODUCTION	9
3.1.	REVISION HISTORY	9
3.2.	AUDIENCE	9
3.3.	REMARKS	9
3.4.	DEFINITIONS, TERMS AND ABBREVIATIONS	10
3.5.	REFERENCES	11
4.	NETWORKING	
4.1.	IMPLEMENTATION MODEL	
4.1.1.		
4.1.2.	!!	
4.1.2.		
4.1.2.	<u>v</u>	
4.1.3.	· · · · · · · · · · · · · · · · · · ·	
4.2.	AE SPECIFICATIONS	
4.2.1.		
4.2.1.	v	
4.2.1.		
4.2.1.		
4.2.1.		
4.2.1.		
4.2.1.		
4.2.1.2		
4.2.1.3	3. Association Initiation Policy	20
4.2.1.	3.1. (Real-World) Activity – Verification as SCU	22
4.2.1.3	3.2. (Real-World) Activity – Modality Worklist as SCU	23
4.2.1.	3.3. (Real-World) Activity – FIND as SCU	25
4.2.1.	3.4. (Real-World) Activity – MOVE as SCU	29
4.2.1.	3.5. (Real-World) Activity – Image Export	30
4.2.1.3	3.6. (Real-World) Activity – Storage Commitment Push Model as SCU	35
4.2.1.	4. Association Acceptance Policy	39
4.2.1.	4.1. (Real-World) Activity – Verification as SCP	39
4.2.1.	4.2. (Real-World) Activity – FIND as SCP	41
4.2.1.	4.3. (Real-World) Activity – MOVE as SCP	43
4.2.1.	4.4. (Real-World) Activity – Image Import	45
4.2.2.	9	
4.2.2.		
4.2.2.2		
4.2.2.2		
4.2.2.2		
4.2.2.2	• • • • • • • • • • • • • • • • • • • •	
4.2.2.2	, ,	
4.2.2.2	U	
4.2.2.3	- · · · · · · · · · · · · · · · · · · ·	
4.2.2.3	, , ,	
4.2.2.4	,	
4.3.	NETWORK INTERFACES	
4.3.1.	7 · · · · · · · · · · · · · · · · · · ·	
4.3.2.		
4.4.	CONFIGURATION	
4.4.1.	AE Title/Presentation Address Mapping	63

4.4.1.1.	Local AE Titles	63
4.4.1.2.	Remote AE Title/Presentation Address Mapping	63
4.4.2.	Parameters	63
5. M	EDIA INTERCHANGE	66
5.1.	IMPLEMENTATION MODEL	66
5.1.1.	Application Data Flow Diagram	66
5.1.2.	Functional Definitions of AE's	
5.1.3.	Sequencing of Real World Activities	66
5.2.	AE SPECIFICATIONS	67
5.2.1.	Media AE Media - Specification	67
5.2.1.1.	File Meta Information for the Media AE	68
5.2.1.2.	Real-World Activities	68
5.2.1.2.		68
5.2.1.2.2		
5.2.1.2.3		
5.3.	AUGMENTED AND PRIVATE APPLICATION PROFILES	
5.4.	MEDIA CONFIGURATION	
6. SI	UPPORT OF CHARACTER SETS	73
7. SI	ECURITY	74
7.1.	SECURITY PROFILES	74
7.1.1.	Security use Profiles	74
7.1.2.	Security Transport Connection Profiles	
7.1.3.	Digital Signature Profiles	
7.1.4.	Media Storage Security Profiles	
7.1.5.	Attribute Confidentiality Profiles	
7.1.6.	Network Address Management Profiles	
7.1.7.	Time Synchronization Profiles	
7.1.8.	Application Configuration Management Profiles	
7.1.9.	Audit Trail Profiles	
7.2.	ASSOCIATION LEVEL SECURITY	
7.3.	APPLICATION LEVEL SECURITY	
8. C	LINICAL APPLICATIONS	77

3. Introduction

The introduction specifies product and relevant disclaimers as well as any general information that the vendor feels is appropriate.

3.1. Revision History

The revision history provides dates and differences of the different releases.

Table 3: Revision History

Document Version	Date of Issue	Status	Description
00	06-September-2013	Authorized	Final version.

3.2. Audience

This Conformance Statement is intended for:

- (Potential) customers
- System integrators of medical equipment
- Marketing staff interested in system functionality
- Software designers implementing DICOM interfaces

It is assumed that the reader is familiar with the DICOM standard.

3.3. Remarks

The DICOM Conformance Statement is contained in chapter 4 through 8 and follows the contents and structuring requirements of DICOM PS 3.2.

This DICOM Conformance Statement by itself does not guarantee successful interoperability of Philips equipment with non-Philips equipment. The user (or user's agent) should be aware of the following issues:

Interoperability

Interoperability refers to the ability of application functions, distributed over two or more systems, to work successfully together. The integration of medical devices into an IT environment may require application functions that are not specified within the scope of DICOM. Consequently, using only the information provided by this Conformance Statement does not guarantee interoperability of Philips equipment with non-Philips equipment.

It is the user's responsibility to analyze thoroughly the application requirements and to specify a solution that integrates Philips equipment with non-Philips equipment.

Validation

Philips equipment has been carefully tested to assure that the actual implementation of the DICOM interface corresponds with this Conformance Statement.

Where Philips equipment is linked to non-Philips equipment, the first step is to compare the relevant Conformance Statements. If the Conformance Statements indicate that successful information exchange should be possible, additional validation tests will be necessary to ensure the functionality, performance, accuracy and stability of image and image related data. It is the responsibility of the user (or user's agent) to specify the appropriate test suite and to carry out the additional validation tests.

• New versions of the DICOM Standard

The DICOM Standard will evolve in future to meet the user's growing requirements and to incorporate new features and technologies. Philips is actively involved in this evolution and plans to adapt its equipment to future versions of the DICOM Standard. In order to do so, Philips reserves the right to make changes to its products or to discontinue its delivery. The user should ensure that any non-Philips provider linking to Philips equipment also adapts to future versions of the DICOM Standard. If not, the incorporation of DICOM enhancements into Philips equipment may lead to loss of connectivity (in case of networking) and incompatibility (in case of media).

3.4. Definitions, Terms and Abbreviations

Table 4: Definitions, Terms and Abbreviations

Abbreviation/Term	Explanation
AE	Application Entity
ANSI	American National Standard Institute
AP	Application Profile
CD	Compact Disc
CD-R	CD-Recordable
CD-M	CD-Medical
CR	Computed Radiography
СТ	Computed Tomography
DCR	Dynamic Cardio Review
DICOM	Digital Imaging and Communications in Medicine
DIMSE	DICOM Message Service Element
DIMSE-C	DIMSE-Composite
DIMSE-N	DIMSE-Normalized
DX	Digital X-Ray
EBE	DICOM Explicit VR Big Endian
ELE	DICOM Explicit VR Little Endian
FSC	File-set Creator
FSR	File-set Reader
FSU	File-set Updater
GUI	Graphic User Interface
HIS	Hospital Information System
HL7	Health Level Seven
ILE	DICOM Implicit VR Little Endian
IOD	Information Object Definition
ISIS	Information System - Imaging System
MOD	Magneto-Optical Disk
MPPS	Modality Performed Procedure Step
MR	Magnetic Resonance
NEMA	National Electrical Manufacturers Association
NM	Nuclear Medicine
PDU	Protocol Data Unit
P-ELE	Private Explicit VR Little Endian
RF	X-Ray Radiofluoroscopic
RIS	Radiology Information System
RT	Radiotherapy
RWA	Real-World Activity
SC	Secondary Capture
SCM	Study Component Management
SCP	Service Class Provider
SCU	Service Class User
SOP	Service Object Pair
TCP/IP	Transmission Control Protocol/Internet Protocol
UID	Unique Identifier
US	Ultrasound
WLM	Worklist Management

3.5. References

[DICOM] Digital Imaging and Communications in Medicine, Parts 1 - 18 (NEMA PS 3.1- PS 3.18),

National Electrical Manufacturers Association (NEMA)

Publication Sales 1300 N. 17th Street, Suite 1752 Rosslyn, Virginia. 22209, United States of America

Document Number: PIIOffc.0000142

Internet: http://medical.nema.org/

Note that at any point in time the official standard consists of the most recent yearly edition of the base standard (currently 2009) plus all the supplements and correction items that have been approved as Final Text.

4. Networking

This section contains the networking related services (vs. the media related ones).

4.1. Implementation model

The implementation model consists of three sections:

- The application data flow diagram, specifying the relationship between the Application Entities and the "external world" or Real-World Activities,
- · A functional description of each Application Entity, and
- The sequencing constraints among them.

4.1.1. Application Data Flow

The Philips IntelliSpace Portal system consists of the following two Application Entities. The Philips IntelliSpace Portal system implements and provides DICOM services using these Application Entities.

- DICOM-Manager
- Print-Manager

The following figure shows the Networking application data flow as a functional overview of the Philips IntelliSpace Portal.




Figure 2: Network Application Data Flow Diagram.

As depicted in the above figure, the Philips IntelliSpace Portal incorporates the following functionality.

- After RWA Request Verification, the Philips IntelliSpace Portal as SCP provides standard Verification Service Class functionality to the requesting SCU.
- After RWA Import Images, the Philips IntelliSpace Portal as SCP provides standard Storage Service Class functionality to the requesting SCU.
- After RWA Query Local Images/Retrieve Local Images, the Philips IntelliSpace Portal as SCP provides standard Query/Retrieve Service Class functionality to the requesting SCU.
- After RWA Export Images (triggered by either the operator or RWA Retrieve Local Images), the Philips IntelliSpace Portal as SCU uses the Remote SCP Storage Service Class functionality to store Local Images on a Remote Database.
- After operator RWA Find Remote Images, the Philips IntelliSpace Portal as SCU uses the remote SCP Query/Retrieve Service Class functionality to query remote images.
- After operator RWA Move Remote Images, the IntelliSpace Portal as SCU uses the remote SCP Query/Retrieve Service Class functionality to retrieve remote images.

- After operator RWA Request Storage Commitment, the Philips IntelliSpace Portal as SCU uses the remote SCP Storage Commitment Service Class functionality to commit remote images.
- After operator RWA Print Images, the Philips IntelliSpace Portal as SCU uses the remote Print Management Service Class to print local images.

4.1.2. Functional Definition of AE's

This section contains a functional definition for each individual local Application Entity.

4.1.2.1. Functional Definition of DICOM Manager

The DICOM Manager as SCU and SCP includes the following service classes:

Storage Service:

When performing a Storage Service Class (SCP), the DICOM Manager will receive images and store them into the system's local database. The same AE may be used (with a configurable different AE title) to access the additional local devices.

Storage Commitment Service:

The DICOM Manager is responsible to issue and support the storage commitment service as SCU.

The DICOM Manager establishes association with the specified AE title and sends storage commitment (N-ACTION) request using the push model. After that, it may accept storage commitment (N-EVENT-REPORT) requests on the same association or by establishing another association.

Query-Retrieve Service:

The DICOM Manager waits for another application to connect at the presentation address configured for its AE title. The DICOM Manager will accept associations with Presentation Contexts for Service Object Pair (SOP) classes for

- Storage Service Classes (C-STORE)
- Query-Retrieve Service Class (C-MOVE and C-FIND only)
- Verification Service Classes.

When performing Query-Retrieve Service Class (C-FIND SCP), the DICOM Manager will query its local database according to the request's parameters, and will send the results to the issuer.

When performing Query-Retrieve Service Class (C-MOVE SCP), the DICOM Manager will issue a C-STORE (SCU) to the target AE for every image found according to the request.

Import Service:

Imported data object received from an external system will be inserted into the local data base with all the original attributes (including private), except those that jeopardize database integrity or further processing by applications.

Export Service:

When an object is exported from the local database to an external device, the attributes will be preserved.

The following figure provides an illustration of DICOM Manager activities:




Figure 3: Illustration of DICOM Manager.

4.1.2.2. Functional Definition of Print Manager

The Print-Manager is a Graphical User Interface (GUI) based application. It enables the user to print predefined images using the DICOM protocol. The user can specify as a printing destination one of several predefined printers. The user can also modify some of the printing parameters such as the film size and format.

The following figure provides an illustration of Print-Manager activities:




Figure 4: Illustration of Print Manager.

4.1.3. Sequencing of Real World Activities

This section contains description of specific sequencing as well as potential constraints of Real-World Activities, including any applicable user interactions, as performed by the DICOM Manager.




Figure 5: RWA Sequencing for Export Images.




Figure 6: RWA Sequencing for Retrieve Local Images.

4.2. AE Specifications

This section in the DICOM Conformance Statement is a set of Application Entity specifications. There are as many of these subsections as there are different AE's in the implementation.

4.2.1. DICOM Manager

Detail of this specific Application Entity is specified in this section.

4.2.1.1. SOP Classes

This Application Entity provides Standard Conformance to the following SOP Classes.

Table 5: SOP Classes for DICOM Manager

SOP Class Name	SOP Class UID	scu	SCP
Verification SOP Class	1.2.840.10008.1.1	Yes	Yes
Storage Commitment Push Model SOP Class	1.2.840.10008.1.20.1	Yes	No
Computed Radiography Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.1	Yes	Yes
Digital X-Ray Image Storage - For Pres. SOP	1.2.840.10008.5.1.4.1.1.1	Yes	Yes
Digital X-Ray Image Storage - For Proc. SOP	1.2.840.10008.5.1.4.1.1.1.1	Yes	Yes
Digital Mammography X-Ray Image Storage - Pres. SOP	1.2.840.10008.5.1.4.1.1.1.2	Yes	Yes
Digital Mammography X-Ray Image Storage - Proc. SOP	1.2.840.10008.5.1.4.1.1.2.1	Yes	Yes
Digital Intra-oral X-Ray Image Storage - Pres. SOP	1.2.840.10008.5.1.4.1.1.3	Yes	Yes
Digital Intra-oral X-Ray Image Storage - Proc. SOP	1.2.840.10008.5.1.4.1.1.3.1	Yes	Yes
Encapsulated PDF Storage	1.2.840.10008.5.1.4.1.1.104.1	Yes	Yes
Grayscale Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.1	Yes	Yes
Color Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.2	Yes	Yes
Pseudo-Color Softcopy Presentation State Storage	1.2.840.10008.5.1.4.1.1.11.3	Yes	Yes
Blending Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.4	Yes	Yes
X-Ray Angiographic Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.12.1	Yes	Yes
K-Ray Radiofluoroscopic Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.12.2	Yes	Yes
Positron Emission Tomography Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.128	Yes	Yes
CT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.2	Yes	Yes
Enhanced CT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.2.1	No	Yes
Nuclear Medicine Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.20	Yes	Yes
MR Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.4	Yes	Yes
RT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.1	Yes	Yes
RT Dose Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.2	Yes	Yes
RT Structure Set Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.3	Yes	Yes
RT Plan Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.5	Yes	Yes
Raw Data Storage SOP Class	1.2.840.10008.5.1.4.1.1.66	Yes	Yes
Spatial Registration Storage	1.2.840.10008.5.1.4.1.1.66.1	Yes	Yes
Real World Value Mapping Storage	1.2.840.10008.5.1.4.1.1.67	Yes	Yes
Secondary Capture Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.7	Yes	Yes
Multi-frame Single Bit Secondary Capture Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.7.1	Yes	Yes
Multi-frame Grayscale Byte SC Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.7.2	Yes	Yes
Multi-frame Grayscale Word SC Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.7.3	Yes	Yes
Multi-frame True Color Secondary Capture Image Storage	1.2.840.10008.5.1.4.1.1.7.4	Yes	Yes
Key Object Selection Document	1.2.840.10008.5.1.4.1.1.88.59	Yes	Yes
General ECG Waveform Storage SOP Class	1.2.840.10008.5.1.4.1.1.9.1.2	Yes	Yes
Study Root QR Information Model - FIND SOP Class	1.2.840.10008.5.1.4.1.2.2.1	Yes	Yes
Study Root QR Information Model - MOVE SOP Class	1.2.840.10008.5.1.4.1.2.2.2	Yes	Yes

SOP Class Name	SOP Class UID	SCU	SCP
Modality Worklist Information Model - FIND SOP Class	1.2.840.10008.5.1.4.31	Yes	No
Philips Private ViewForum 3D Volume New Storage	1.3.46.670589.5.0.1.1	Yes	Yes

Note: Any SOP specific behavior is documented later in the conformance statement in the applicable SOP specific conformance section.

The following SOP Classes are only supported for storage (not for viewing/processing):

Table 6: Network Services that are only supported for Storage

SOP Class Name	SOP Class UID	scu	SCP
RT Plan Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.5	Yes	Yes
RT Dose Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.2	Yes	Yes
Key Object Selection Document	1.2.840.10008.5.1.4.1.1.88.59	Yes	Yes
Raw Data Storage SOP Class	1.2.840.10008.5.1.4.1.1.66	Yes	Yes
Spatial Registration Storage	1.2.840.10008.5.1.4.1.1.66.1	Yes	Yes
Color Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.2	Yes	Yes
Pseudo-Color Softcopy Presentation State Storage	1.2.840.10008.5.1.4.1.1.11.3	Yes	Yes
Blending Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.4	Yes	Yes
Multi-frame Grayscale Word SC Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.7.3	Yes	Yes
Multi-frame Single Bit Secondary Capture Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.7.1	Yes	Yes

The next IODs (as configured in LanConfig by FSE) can be blocked with the Blocking Filter in Philips IntelliSpace Portal.

Table 7: The IODS can be blocked with the blocking filter in Philips IntelliSpace Portal

SOP Class Name	SOP Class UID	SCU	SCP
Encapsulated PDF Storage	1.2.840.10008.5.1.4.1.1.104.1	Yes	Yes
General ECG Waveform Storage SOP Class	1.2.840.10008.5.1.4.1.1.9.1.2	Yes	Yes
Key Object Selection Document	1.2.840.10008.5.1.4.1.1.88.59	Yes	Yes

4.2.1.2. Association Policies

Each AE specification contains a description of the general association establishment and acceptance policies of the AE.

With incoming association requests the system allows acceptance of a range of defined IP addresses which is configurable in the LanConfig application.

4.2.1.2.1. General

The DICOM standard application context is specified below.

Table 8: DICOM Application Context

Description	Value
Application Context Name	1.2.840.10008.3.1.1.1

4.2.1.2.2. Number of Associations

The number of simultaneous associations that an Application Entity may support as a Initiator or Acceptor is specified here.

Table 9: Number of associations as an Association Initiator for this AE

Description	Value
Maximum number of simultaneous associations	50

Table 10: Number of associations as an Association Acceptor for this AE

Description	Value
Maximum number of simultaneous associations	50

4.2.1.2.3. Asynchronous Nature

The implementation supports negotiation of multiple outstanding transactions, along with the maximum number of outstanding transactions supported.

Table 11: Asynchronous nature as an Association Initiator for this AE

Description	Value
Maximum number of outstanding asynchronous transactions	1

4.2.1.2.4. Implementation Identifying Information

The value supplied for Implementation Class UID and version name are documented here.

Table 12: DICOM Implementation Class and Version for DICOM Manager

Implementation Class UID	1.3.46.670589.33.1.1
Implementation Version Name	BRCONN_4.0

4.2.1.2.5. Communication Failure Handling

The behavior of the AE during communication failure is summarized in the next table.

Table 13: Communication Failure Behavior

Exception	Behavior	Comment
ARTIM Timeout	The system stops the ARTIM timer and closes the transport connection.	Configurable, minimum value=1.
Association Timeout	A release request is sent in order to close the association.	Configurable, minimum value=1.

4.2.1.3. Association Initiation Policy

The Application Entity will respond to a received Association rejection as shown in the next table.

Table 14: Association Rejection response

Result	Source	Reason/Diagnosis	Behavior
1 - rejected- permanent	1 - DICOM UL service-user	1 - no-reason-given	The connection is closed.
		2 - application-context-name-not supported	The connection is closed.

Result	Source	Reason/Diagnosis	Behavior
		3 - calling-AE-title-not-recognized	The connection is closed.
		7 - called-AE-title-not-recognized	The connection is closed.
	2 - DICOM UL service-provider (ACSE related function)	1 - no-reason-given	The connection is closed.
		2 - protocol-version-not-supported	The connection is closed.
	3 - DICOM UL service-provider (Presentation related function)	1 - temporary-congestion	The connection is closed.
		2 - local-limit-exceeded	The connection is closed.
2 - rejected-transient	1 - DICOM UL service-user	1 - no-reason-given	The connection is closed.
		2 - application-context-name-not- supported	The connection is closed.
		3 - calling-AE-title-not-recognized	The connection is closed.
		7 - called-AE-title-not-recognized	The connection is closed.
	2 - DICOM UL service-provider (ACSE related function)	1 - no-reason-given	The connection is closed.
		2 - protocol-version-not-supported	The connection is closed.
	3 - DICOM UL service-provider (Presentation related function)	1 - temporary-congestion	The connection is closed.
		2 - local-limit-exceeded	The connection is closed.

The behavior of the AE on receiving an Association abort is summarized in the next table.

Table 15: Association Abort Handling

Source	Reason/Diagnosis	Behavior
0 - DICOM UL service-user (initiated abort)	0 - reason-not-specified	The connection is closed.
2 - DICOM UL service-provider (initiated abort)	0 - reason-not-specified	The connection is closed.
	1 - unrecognized-PDU	The connection is closed.
	2 - unexpected-PDU	The connection is closed.
	4 - unrecognized-PDU-parameter	The connection is closed.
	5 - unexpected-PDU-parameter	The connection is closed.
	6 - invalid-PDU-parameter-value	The connection is closed.

The behavior of the AE for sending an association abort is summarized in next table.

Table 16: DICOM Association Abort Policies.

Source	Reason/Diagnosis	Behavior
0 - DICOM UL service- user	0 - reason-not- specified	When the system tries to disconnect before receiving an association accept but after sending association request; When receiving association accept with no presentation context item; When receiving association accept where all items in the presentation context item list are not accepted by remote system; When an association timeout (configurable per remote device) expired (timeout which determines how long to keep an idle association); When receiving a PDU whose size is bigger than the agreed max PDU size.

Source	Reason/Diagnosis	Behavior
2 - DICOM UL service- provider	1- unrecognized- PDU	Whenever the system receives unexpected or unrecognized PDU (according to the DICOM UPPER LAYER PROTOCOL STATE TRANSITION TABLE in chapter 8 of the DICOM standard).
Other	Other	Not applicable.

4.2.1.3.1. (Real-World) Activity - Verification as SCU

4.2.1.3.1.1. Description and Sequencing of Activities




Figure 7: (Real World) Activity - Verification as SCU.

DICOM Manager initiates an association when the user points to one of the icons in the devices tool-bar in Philips IntelliSpace Portal UI, clicks the right mouse button and selects "Verify Connection" operation.

4.2.1.3.1.2. Proposed Presentation Contexts

Each time an association is initiated, the association initiator proposes a number of presentation contexts to be used on that association. The association will be closed immediately upon receiving the response.

The presentation contexts proposed by DICOM Manager for (Real-World) Activity - Verification as SCU are defined in the following table.

Presentation Context Table Abstract Syntax Transfer Syntax Extended Role Negotiation Name **UID Name List UID List** Verification SOP Class SCU 1.2.840.10008.1.1 Explicit VR Little Endian 1.2.840.10008.1.2.1 None Implicit VR Little Endian 1.2.840.10008.1.2

Table 17: Proposed Presentation Contexts for (Real-World) Activity – Verification as SCU

Note: The default supported Transfer Syntax is ILE. ELE has preference over ILE.

4.2.1.3.1.3. SOP Specific Conformance for Verification SOP Class

DICOM Manager provides standard conformance to the DICOM V3.0.

4.2.1.3.1.3.1. Dataset Specific Conformance for Verification C-ECHO SCU

This part of the section includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 18: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Success	The SCU has successfully send C-ECHO.
Other than Success	<>0000	Problems with sending the C-ECHO	The SCU failed to send the C-ECHO; user is notified.

4.2.1.3.2. (Real-World) Activity - Modality Worklist as SCU

4.2.1.3.2.1. Description and Sequencing of Activities




Figure 8: Data Flow Diagram - Modality Worklist as SCU.

4.2.1.3.2.2. Proposed Presentation Contexts

The presentation contexts are defined in the next table.

Table 19: Proposed Presentation Contexts for (Real-World) Activity - Modality worklist as SCU

Presentation Context Table						
Abstrac	Data	Extended				
Name	UID	Name List	UID List	Role	Negotiation Negotiation	
Modality Worklist Information Model - FIND SOP Class	1.2.840.10008.5.1.4.31	Explicit VR Big Endian	1.2.840.10008.1.2.2	SCU None	None	
		Explicit VR Little Endian	1.2.840.10008.1.2.1			
		Implicit VR Little Endian	1.2.840.10008.1.2			

4.2.1.3.2.3. SOP Specific Conformance for Modality Worklist Information Model - FIND SOP Class

4.2.1.3.2.3.1. Dataset Specific Conformance for Modality Worklist Information Model - FIND SOP Class C-FIND-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

The table below should be read as follows:

Attribute Name: Attributes supported to build a Modality Worklist Request Identifier.

Tag: DICOM tag for this attribute.

VR: DICOM VR for this attribute.

M: Matching Keys for (automatic) Worklist Update.

R: Return Keys. An "X" will indicate that this attribute as matching key can be used.

Q: Interactive Query Key. An "X" will indicate that this attribute as matching key can be used.

D: Displayed Keys. An "X" indicates that this Worklist attribute is displayed o the user during a patient

registration dialog.

IOD: An "X" indicates that this Worklist attribute is included into all object Instances created during

performance of the related Procedure Step.

Type of matching: The following types of matching exists:

Single Value Matching List of UID Matching Wild Card Matching Range Matching Sequence Matching Universal Matching

Table 20: Worklist Request Identifier

Attribute Name	Tag	VR	M	R	Q	D	IOD	Type of Matching	Comment
				Pat	ient	Ide	ntificat	tion Module	
Patient's Name	0010,0010	PN		Χ					
Patient ID	0010,0020	LO		Χ					
			Sc	hed	luled	l Pro	cedur	e Step Module	
Scheduled Procedure Step Sequence	0040,0100	SQ		X					
>Modality	0008,0060	CS	Χ					Single Value	
>Scheduled Procedure Step Start Date	0040,0002	DA	Χ					Range, Single Value	

Note: IntelliSpace Portal gets the scheduled worklist for the day and fetch priors for some of these orders before execution, so when new exams arrive on Portal, priors are already available (no need for manual Query/Retrieve from PACS).

Table 21: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Matching is complete	Successfully returned all matching information
Other than Success	<>0000	Matching is incomplete/failed	A message is logged.

4.2.1.3.3. (Real-World) Activity – FIND as SCU

4.2.1.3.3.1. Description and Sequencing of Activities

DICOM-Manager initiates an association when the user clicks on one of the icons in the devices tool-bar. The DICOM-Manager searches (C-FIND) by Study Level following by Series level and, optionally (configurable), by Image Level.




Figure 9: (Real World) Activity - Find as SCU.

4.2.1.3.3.2. Proposed Presentation Contexts

Each time an association is initiated, the association initiator proposes a number of presentation contexts to be used on that association. In this subsection, the presentation contexts proposed by Archive-Manager for (Real-World) Activity - Find as SCU are defined in the Table below.

Table 22: Proposed Presentation Contexts for (Real-World) Activity – FIND As SCU

Presentation Context Table							
Abstrac	Syntax	Data	Extended				
Name	UID	Name List	UID List	Role	Negotiation		
Study Root QR Information	1.2.840.10008.5.1.4.1.2.2.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None		
Model - FIND SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2				

4.2.1.3.3.3. SOP Specific Conformance for Study Root QR Information Model - FIND SOP Class

The DICOM-Manager provides standard conformance to the DICOM V3.0.

4.2.1.3.3.3.1. Dataset Specific Conformance for Study Root QR Information Model - FIND SOP Class C-FIND-SCU Table 23: Supported Query Keys for Study Root Information Model

			Study Root Information Model	
Attribute Name	Tag	VR	Type Of Matching	Comment
Query/Retrieve Level	0008,0052	cs	Single Value	STUDY,SERIES,IMAGE
Specific Character Set	0008,0005	CS		None
			Q/R Study level	
Accession Number	0008,0050	SH	Single Value, Universal, WildCard	User Input
Modalities in Study	0008,0061	CS	Single Value, Universal	System/User Input
Number of Study Related Instances	0020,1208	IS	Universal	System
Number of Study Related Series	0020,1206	IS	Universal	System
Patient ID	0010,0020	LO	Single Value, Universal, WildCard	User Input
Patient's Birth Date	0010,0030	DA	Range, Single Value, Universal	System
Patient's Birth Time	0010,0032	TM	Sequence, Universal, WildCard, Range	System
Patient's Name	0010,0010	PN	Single Value, Universal, WildCard	User Input. It is case sensitive.
Patient's Sex	0010,0040	CS	Single Value, Universal, WildCard	User Input
Referring Physician's Name	0008,0090	PN	Range, Single Value, Universal, WildCard	User Input
Study Date	0008,0020	DA	Range, Single Value, Universal	User Input
Study Time	0008,0030	TM	Single Value, Universal	None
Study Description	0008,1030	LO	Single Value, Universal, WildCard	System/User Input
Name of Physician(s) Reading Study	0008,1060	PN	Single Value, Universal, WildCard	System
Admitting Diagnoses Description	0008,1080	LO	Single Value, Universal, WildCard	System
Issuer of Patient ID	0010,0021	LO	Single Value, Universal, WildCard	System
Other Patient IDs	0010,1000	LO	Single Value, Universal, WildCard	System
Other Patient Names	0010,1001	PN	Single Value, Universal, WildCard	System
Patient's Age	0010,1010	AS	Single Value, Universal	System
Patient's Size	0010,1020	DS	Single Value, Universal	System
Patient's Weight	0010,1030	DS	Single Value, Universal	System
Ethnic Group	0010,2160	SH	Single Value, Universal, WildCard	System
Occupation	0010,2180	SH	Single Value, Universal, WildCard	System
Additional Patient History	0010,21B0	LT	Single Value, Universal, WildCard	System
Patient Comments	0010,4000	LT	Single Value, Universal, WildCard	System
Study ID	0020,0010	SH	Single Value, Universal, WildCard	User Input
Study Instance UID	0020,000D	UI	Single Value, Universal, WildCard, List Of UID	System
Other Study Numbers	0020,1070	IS	Single Value, Universal	
Number of patient related studies	0020,1200	IS	Universal	
Number of patient related series	0020,1202	IS	Universal	
Number of patient related instances	0020,1204	IS	Universal	
Number of study related series	0020,1206	IS	Universal	
Number of study related instances	0020,1208	IS	Universal	
Interpretation Author	4008,010C	PN	Single Value, Universal, WildCard	

	Q/R Series level					
Body Part Examined	0018,0015	CS	Universal, Single Value, WildCard	System		
Manufacturer	0008,0070	LO	Universal	System		
Modality	0008,0060	CS	Universal, Single Value	System		
Number of Series Related Instances	0020,1209	IS	Universal	System		
Performed Procedure Step ID	0040,0253	SH	Universal	System		
Performed Procedure Step Description	0040,0254	LO	Single Value, Universal	System		
Performed Procedure Step Start Date	0040,0244	DA	Universal	System		
Performed Procedure Step Start Time	0040,0245	TM	Single Value	System		
Protocol Name	0018,1030	LO	Single Value, Universal	System		
Series Date	0008,0021	DA	Single Value, Universal	System		
Series Description	0008,103E	LO	Universal	System		
Series Instance UID	0020,000E	UI	Universal	System		
Series Number	0020,0011	IS	Universal, Single Value	System		
Series Time	0008,0031	TM	Universal	System		
Study Instance UID	0020,000D	UI	Single Value, Universal, List Of UID	System		
Request Attributes Sequence	0040,0275	SQ	Universal	System		
>Requested Procedure ID	0040,1001	SH	Universal			
>Scheduled Procedure Step ID	0040,0009	SH	Universal			
			Q/R Image level			
Columns	0028,0011	US	Universal	System		
Contrast/Bolus Agent	0018,0010	LO	Universal	System		
Frame of Reference UID	0020,0052	UI	Universal	System		
Image Orientation (Patient)	0020,0037	DS	Universal	System		
Image Type	8000,8000	CS	Universal	System		
Instance Creation Date	0008,0012	DA	Universal	System		
Instance Creation Time	0008,0013	TM	Universal	System		
Instance Number	0020,0013	IS	Single Value, Universal	System		
KVP	0018,0060	DS	Universal	System		
Patient Orientation	0020,0020	CS	Universal	System		
Photometric Interpretation	0028,0004	CS	Universal	System		
Pixel Spacing	0028,0030	DS	Universal	System		
Rows	0028,0010	US	Universal	System		
Samples per Pixel	0028,0002	US	Universal	System		
Series Instance UID	0020,000E	UI	Universal, Single Value, List Of UID	System		
Slice Location	0020,1041	DS	Universal	System		
Slice Thickness	0018,0050	DS	Universal	System		
Related General SOP Class UID	0018,001A	UI	Single Value, Universal, List Of UID	System		
SOP Class UID	0008,0016	UI	Universal, Single Value, List Of UID	System		
SOP Instance UID	0008,0018	UI	Universal, Single Value, List Of UID	System		
Content Date	0008,0023	DA	Universal			
Content Time	0008,0033	TM	Universal			
SOP Classes in Study	0008,0062	UI	Universal	System		
Study Instance UID	0020,000D	UI	Universal, Single Value, List Of UID	System		
			, ,			

Table 24: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Success	Matching is successful.
Failure	A700	Refused - Out of resources	
	A900	Failed - Doesn't match SOP class	
	Cxxx	Failed - Unknown reason	

4.2.1.3.4. (Real-World) Activity – MOVE as SCU

4.2.1.3.4.1. Description and Sequencing of Activities

The RWA Move Remote Images involves the retrieve of images on a remote system by moving (copying) the matching images from the remote database to another database.

The operator is able to copy the selected images in a patient folder from a remote database to another, local or remote, database by means of the copy tool in the DICOM Manager data handling facility. The DICOM Manager initiates for each copy request an association to the selected peer entity (Remote AE) and uses it to send the Retrieve (C-MOVE) request (and receive the associated responses). The association is released after the final Retrieve (C-MOVE) response for the related request has been received with the status success / failure.




Figure 10: (Real World) Activity - Move as SCU.

4.2.1.3.4.2. Proposed Presentation Contexts

Each time an association is initiated, the association initiator proposes a number of presentation contexts to be used on that association.

In this subsection, the presentation contexts proposed by DICOM-Manager for (Real-World) Activity - Move as SCU are defined in the following table.

Table 25: Proposed Presentation Contexts for (Real-World) Activity - MOVE as SCU

Presentation Context Table								
Abstrac	t Syntax	Transfer S	Syntax		Extended Negotiation			
Name	UID	Name List	UID List	Role				
Study Root QR Information	1.2.840.10008.5.1.4.1.2.2.2	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
Model - MOVE SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2					

4.2.1.3.4.3. SOP Specific Conformance for Study Root QR Information Model - MOVE SOP Class

DICOM-Manager provides standard conformance to the DICOM V3.0 Query/Retrieve Service Class as an SCU for the SOP Class Study Root Query/Retrieve Information Model - Move.

4.2.1.3.4.3.1. Dataset Specific Conformance for Study Root QR Information Model - MOVE SOP Class C-MOVE-SCU

Table 26: Identifiers for MOVE Study Root Information Model as SCU

Study Root Information Model					
Attribute Name	Tag	VR	Comment		
Query/Retrieve Level	0008,0052	CS			
			Q/R Study level		
Study Instance UID	0020,000D	UI			
			Q/R Series level		
Series Instance UID	0020,000E	UI			
Study Instance UID	0020,000D	UI			
			Q/R Image level		
Series Instance UID	0020,000E	UI			
SOP Instance UID	0008,0018	UI			
Study Instance UID	0020,000D	UI			

Table 27: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Success	Storage successful.
Failure	A701	Refused - Out of Resources	Message by transfer result - Unable to calculate number of matches.
	A702	Refused - Out of Resources	Message by transfer result - Unable to perform sub operations
	A801	Refused - Move Destination Unknown	Message by transfer result - Move Destination Unknown.
	A900	Error - Identifier Does Not Match SOP Class	Message by transfer result - Identifier does not match SOP Class.
	Cxxx	Error - Unable to Process	Message by transfer result - Unable to process.
Warning	B000	Sub-operations complete - One or more failures	Message by transfer result - Sub operations complete one or more failures.
Cancel	FE00	Cancel	Move operation cancelled.

4.2.1.3.5. (Real-World) Activity – Image Export

4.2.1.3.5.1. Description and Sequencing of Activities




Figure 11: (Real World) Activity - Image Export.

The associated Real-World Activity is a request for retrieval of images from the disk or save operation from Philips IntelliSpace Portal applications and storage of the images to a remote system using a C-STORE command.

4.2.1.3.5.2. Proposed Presentation Contexts

Each time an association is initiated, the association initiator proposes a number of presentation contexts to be used on that association.

The system configuration (by FSE in LanConfig) allows disabling individually each of the supported syntaxes per remote device when establishing and accepting associations. At least one of the syntaxes will be enabled.

When establishing association to a remote device, all the enabled (for that device) syntaxes will be proposed based on the SOP Class. If more than one Transfer Syntax is accepted by the SCP, the order of selecting the syntax to use is: P-ELE, JPEG, ELE and ILE. However if the proposed SOP class does not contain any pixel data then only ELE and ILE will be proposed.

When a device is newly added in LanConfig, by default the selected transfer syntaxes for the device are ELE & ILE. If the device is a Philips device which is more recent than Philips IntelliSpace Portal then P-ELE will also selected by default. The user will have the option of changing the selected transfer syntax per device using LanConfig. Philips IntelliSpace Portal supports Level2 DICOM transparency and hence will preserve all the source image data.

The presentation contexts proposed by the DICOM Manager for (Real-World) Activity (C-STORE SCU) are defined in the following table.

Table 28: Proposed Presentation Contexts for (Real-World) Activity – Image Export

Presentation Context Table								
Abstrac	t Syntax	Transfer	Transfer Syntax					
Name	UID	Name List	UID List	Role	Negotiation			
Computed Radiography Image	1.2.840.10008.5.1.4.1.1.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None			
Storage SOP Class		Explicit VR Little Endian	1.2.840.10008.1.2.1					

	Presen	tation Context Table			
Abstrac	t Syntax	Transfe	r Syntax	Role	Extended
Name	UID	Name List	UID List	Kole	Negotiation
		Implicit VR Little Endian JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2 1.2.840.10008.1.2.4.70		
Digital X-Ray Image Storage - For Pres. SOP	1.2.840.10008.5.1.4.1.1.1.1	CT-private-ELE Explicit VR Little Endian Implicit VR Little Endian JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.3.46.670589.33.1.4.1 1.2.840.10008.1.2.1 1.2.840.10008.1.2 1.2.840.10008.1.2.4.70	SCU	None
Digital X-Ray Image Storage - For Proc. SOP	1.2.840.10008.5.1.4.1.1.1.1.1	CT-private-ELE Explicit VR Little Endian Implicit VR Little Endian JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.3.46.670589.33.1.4.1 1.2.840.10008.1.2.1 1.2.840.10008.1.2 1.2.840.10008.1.2	SCU	None
Digital Mammography X-Ray Image Storage - Pres. SOP	1.2.840.10008.5.1.4.1.1.1.2	CT-private-ELE Explicit VR Little Endian Implicit VR Little Endian JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.3.46.670589.33.1.4.1 1.2.840.10008.1.2.1 1.2.840.10008.1.2 1.2.840.10008.1.2.4.70	SCU	None
Digital Mammography X-Ray Image Storage - Proc. SOP	1.2.840.10008.5.1.4.1.1.1.2.1	CT-private-ELE Explicit VR Little Endian Implicit VR Little Endian JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.3.46.670589.33.1.4.1 1.2.840.10008.1.2.1 1.2.840.10008.1.2 1.2.840.10008.1.2.4.70	SCU	None
Digital Intra-oral X-Ray Image Storage - Pres. SOP	1.2.840.10008.5.1.4.1.1.1.3	CT-private-ELE Explicit VR Little Endian Implicit VR Little Endian JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.3.46.670589.33.1.4.1 1.2.840.10008.1.2.1 1.2.840.10008.1.2 1.2.840.10008.1.2.4.70	SCU	None
Digital Intra-oral X-Ray Image Storage - Proc. SOP	1.2.840.10008.5.1.4.1.1.1.3.1	CT-private-ELE Explicit VR Little Endian Implicit VR Little Endian JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.3.46.670589.33.1.4.1 1.2.840.10008.1.2.1 1.2.840.10008.1.2 1.2.840.10008.1.2.4.70	SCU	None
Encapsulated PDF Storage	1.2.840.10008.5.1.4.1.1.104.1	Explicit VR Little Endian Implicit VR Little Endian	1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCU	None
Grayscale Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.1	Explicit VR Little Endian Implicit VR Little Endian	1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCU	None
Color Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.2	Explicit VR Little Endian Implicit VR Little Endian	1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCU	None
Pseudo-Color Softcopy Presentation State Storage	1.2.840.10008.5.1.4.1.1.11.3	Explicit VR Little Endian Implicit VR Little Endian	1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCU	None

	Presen	tation Context Table			
Abstrac	t Syntax	Transfe	r Syntax	Role	Extended
Name	UID	Name List	UID List		Negotiation
Blending Softcopy Presentation	1.2.840.10008.5.1.4.1.1.11.4	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None
State Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2		
X-Ray Angiographic Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.12.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None
Glorage GOT Class		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
X-Ray Radiofluoroscopic Image	1.2.840.10008.5.1.4.1.1.12.2	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None
Storage SOP Class		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Positron Emission Tomography	1.2.840.10008.5.1.4.1.1.128	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None
Image Storage SOP Class		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
CT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.2	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Nuclear Medicine Image	1.2.840.10008.5.1.4.1.1.20	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None
Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2		
MR Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.4	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
RT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
RT Dose Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.2	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
RT Structure Set Storage SOP	1.2.840.10008.5.1.4.1.1.481.3	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None
Class		Implicit VR Little Endian	1.2.840.10008.1.2		

Presentation Context Table								
Abstract Syntax		Transfer Syntax			Extended			
Name	UID	Name List	UID List	Role	Negotiation			
RT Plan Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.5	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
		Implicit VR Little Endian	1.2.840.10008.1.2					
Raw Data Storage SOP Class	1.2.840.10008.5.1.4.1.1.66	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
		Implicit VR Little Endian	1.2.840.10008.1.2					
Spatial Registration Storage	1.2.840.10008.5.1.4.1.1.66.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None			
		Explicit VR Little Endian	1.2.840.10008.1.2.1					
		Implicit VR Little Endian	1.2.840.10008.1.2					
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70					
Real World Value Mapping	1.2.840.10008.5.1.4.1.1.67	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
Storage		Implicit VR Little Endian	1.2.840.10008.1.2					
Secondary Capture Image	1.2.840.10008.5.1.4.1.1.7	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None			
Storage SOP Class		Explicit VR Little Endian	1.2.840.10008.1.2.1					
		Implicit VR Little Endian	1.2.840.10008.1.2					
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70					
Multi-frame Single Bit	1.2.840.10008.5.1.4.1.1.7.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
Secondary Capture Image Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2					
Multi-frame Grayscale Byte SC	1.2.840.10008.5.1.4.1.1.7.2	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
Image Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2					
Multi-frame Grayscale Word SC	1.2.840.10008.5.1.4.1.1.7.3	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
Image Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2					
Multi-frame True Color	1.2.840.10008.5.1.4.1.1.7.4	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
Secondary Capture Image Storage		Implicit VR Little Endian	1.2.840.10008.1.2					
Key Object Selection Document	1.2.840.10008.5.1.4.1.1.88.59	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
		Implicit VR Little Endian	1.2.840.10008.1.2					
General ECG Waveform	1.2.840.10008.5.1.4.1.1.9.1.2	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2					
Philips Private ViewForum 3D	1.3.46.670589.5.0.1.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCU	None			
Volume New Storage		Explicit VR Little Endian	1.2.840.10008.1.2.1					
		Implicit VR Little Endian	1.2.840.10008.1.2					
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70					

[&]quot;JPEG" here refers to JPEG Lossless, Non-Hierarchical, First-Order Prediction (Process 14 [Selection Value 1]): Default Transfer Syntax for Lossless JPEG Image Compression.

It will apply the following priorities to the choice of Transfer Syntax which can be configured in LAN Config Tool:

Table 29: Transfer Syntax Priorities.

Transfer Syntax	UID	Comment
Private DICOM Explicit VR Little Endian (CT-private- ELE)	1.3.46.670589.33.1.4.1	LanConfig. Default for Philips IntelliSpace Portal.
2. DICOM JPEG Lossless, Non-Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70	LanConfig, Transfer Syntax for Lossless JPEG Image Compression (JPEG).
3. DICOM Explicit VR Little Endian	1.2.840.10008.1.2.1	LanConfig.
4. DICOM Implicit VR Little Endian	1.2.840.10008.1.2	LanConfig, default.

Note: No support of JPEG & P-ELE transfer syntaxes for all SOP classes without pixel data.

4.2.1.3.5.3. SOP Specific Conformance for Storage SOP Classes

DICOM Manager AE provides standard conformance to the DICOM V3.0 Storage Service Class as an SCU for SOP Classes mentioned in the previous section.

Any unsuccessful status (error or warning), returned in the C-STORE Response, results in termination of sending further C-STORE requests (if any in the queue) and reporting of the error to the system log file and UI (Queue Manager)

There are two timeouts for the association. One timeout, "Association Timeout" is used to close an idle association. For C-STORE the default is 120 sec and can be configured per remote DICOM node. The other timeout is "Service Timeout" which detects that no data is transmitted over the association and closes it. The default "Service Timeout" for C-STORE is 5 minutes.

4.2.1.3.5.3.1. Dataset Specific Conformance for C-STORE-RQ

Detail regarding the Dataset Specific response behavior will be reported in this section.

This includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 30: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Success	Storage successful.
Failure	0122	Refused - SOP Class not supported	Message by transfer result - Unknown reason.
	A700	Refused - Out of Resources	Message by transfer result - Out of Resources.
	A900	Error - Data Set does not match SOP	Message by transfer result - Unknown reason.
	C000	Error - Cannot understand	Message by transfer result - Store failed.
Warning	B000	Coercion of Data Elements	Warning status is treated as success.
	B007	Data Set does not match SOP Class	Warning status is treated as success.
	B006	Elements Discarded	Warning status is treated as success.

4.2.1.3.6. (Real-World) Activity – Storage Commitment Push Model as SCU

4.2.1.3.6.1. Description and Sequencing of Activities




Figure 12: (Real World) Activity- DICOM Manager (Storage Commitment).

DICOM-Manager will attempt to initiate a new association when requested to commit the images that were stored on a remote device, which supports the storage Commitment Service.

The associated real world activity for the N-ACTION is a storage commitment request to the remote storage device.

The associated real world activity for the N-EVENT-REPORT operation is the completion of the storage commitment by the remote device.

This can be as Synchronous storage commitment as the N-EVENT-REPORT-RQ is received inside the configure timeout or as Asynchronous storage commitment after the Release-RQ by the timeout is already send to the remote system.

DICOM-Manager will issue a failure status if it is unable to properly handle the storage commitment report event.

4.2.1.3.6.2. Proposed Presentation Contexts

Each time an association is initiated, the association initiator proposes a number of presentation contexts to be used on that association.

The presentation contexts proposed by DICOM Manager for (Real-World) Activity - Storage Commitment as SCU are defined in the following table.

Table 31: Proposed Presentation Contexts for (Real-World) Activity – Storage Commitment Push Model AS SCU

Presentation Context Table						
Abstract Syntax Transfer Syntax					Extended	
Name	UID	Name List	UID List	Role	Negotiation	
Storage Commitment Push	1.2.840.10008.1.20.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None	
Model SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2			

4.2.1.3.6.3. SOP Specific Conformance for Storage Commitment Push Model SOP Class

DICOM-Manager provides standard conformance to the DICOM V3.0 Storage Commitment Service Class using Push Model as an SCU.

Multiple N-ACTION-RQ can be performed over a single association. Multiple N-EVENT-REPORT-RQ can be accepted over a single association. After all N-ACTION-RQ that are waiting in the stack are issued, association will be closed with the timeout which is configurable using LanConfig.

A remote system reports about storage commitment completion using an N-EVENT-REPORT-RQ command. The system can also accept the N-EVENT-REPORT-RQ commands over a separate association initiated by the remote system, using reverse role negotiation.

Storage Commitment for individual images are grouped into large "chunks" and issued as a single Storage Commitment request.

Table 32: DICOM Command Communication Failure Bahavior Storage Commitment.

Exception	Behavior
ARTIM Time-out	The reason in logged
Reply Time-out	The association is released. Continues with waiting for storage commitment
Association Time-out SCU	The association is released. Continues with waiting for storage commitment
Association aborted	Continues with waiting for storage commitment

4.2.1.3.6.3.1. Dataset Specific Conformance for Storage Commitment Push Model SOP Class N-EVENT-REPORT-SCP

All details regarding the specific conformance, including response behavior to all status codes, both from an application level and communication errors are provided in following tables for N-EVENT-REPORT.

Table 33: Storage Commitment N-EVENT-REPORT Behavior.

Event Type Name	Event Type	Behavior
Storage Commitment Request Successful	1	Awaiting Storage Commitment request will be moved to complete in Queue Manager.
Storage Commitment Request Complete - Failures Exist	2	Awaiting Storage Commitment request will be moved to fail in Queue Manager.

Table 34: Storage Commitment N-EVENT-REPORT Failure Handling Behavior

Service Status	Error Code	Further Meaning	Description
Success	0000	Success	The storage commitment result has been successfully received.

4.2.1.3.6.3.2. Dataset Specific Conformance for Storage Commitment Push Model SOP Class N-ACTION-SCU

All details regarding the specific conformance, including response behavior to all status codes, both from an application level and communication errors are provided in following tables for N-ACTION.

Table 35: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Success	The request for storage commitment is considered successfully stored.
Other than Success	<>0000	Problems with sending the N-ACTION Request	The request for storage commitment is marked as failed.

4.2.1.4. Association Acceptance Policy

The Application Entity may reject Association attempts as shown in the table below.

Table 36: Association Rejection Policies.

Result	Source	Reason/Diagnosis	Behavior
1 - rejected permanent	•	2 - application-context-name- not-supported	When receiving association request and the application context name is not supported.
		3 - calling-AE-title-not-recognized	When receiving association request and the calling AE title is not supported.
		7 - called-AE-title-not- recognized	When receiving association request and the called AE title is not supported.
	2 - DICOM UL service provider (ACSE related function)	1 - no-reason-given	When receiving association request and all of the items in the presentation context item list are not supported by the system.
		2 - protocol-version-not- supported	When receiving an association request and the protocol version received is not supported.

The behavior of the AE on DICOM receiving Association Abort Handling is summarized in table below:

Table 37: DICOM receiving Association Abort Handling.

Source	Reason/Diagnosis	Behavior
0 - DICOM UL service-user (initiated abort)	0 - reason-not-specified	The connection is closed.
2 - DICOM UL service-provider (initiated abort)	0 - reason-not-specified	The connection is closed.
	1 - unrecognized-PDU	The connection is closed.
	2 - unexpected-PDU	The connection is closed.
	4 - unrecognized-PDU parameter	The connection is closed.
	5 - unexpected-PDU parameter	The connection is closed.
	6 - invalid-PDU-parameter value	The connection is closed.

The behavior of the AE for sending an association abort is summarized in next table.

Table 38: Association Abort Policies.

Source	Reason/Diagnosis	Behavior
0 - DICOM UL service- user (initiated abort)	0 - reason-not- specified	When an association timeout (configurable per remote device) expired (timeout which determines how long to keep an idle association). When receiving a PDU whose size is bigger than the agreed max PDU size.
2 - DICOM UL service- provider (initiated abort)	1 - unrecognized- PDU	Whenever the system receives unexpected or unrecognized PDU (according to the DICOM UPPER LAYER PROTOCOL STATE TRANSITION TABLE in chapter 8 of the DICOM standard).

4.2.1.4.1. (Real-World) Activity - Verification as SCP

4.2.1.4.1.1. Description and Sequencing of Activities

A remote system requests verification from DICOM Manager using the C-ECHO command.




Figure 13: (Real World) Activity - Verification as SCP.

4.2.1.4.1.2. Accepted Presentation Contexts

The presentation contexts are defined in next table.

Table 39: Acceptable Presentation Contexts for (Real-World) Activity - Verification as SCP

Presentation Context Table							
Abstract Syntax Transfer Syntax				Dala	Extended		
Name	UID	Name List	UID List	Role	Negotiation		
Verification SOP Class	1.2.840.10008.1.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None		
		Implicit VR Little Endian	1.2.840.10008.1.2				

4.2.1.4.1.3. SOP Specific Conformance for Verification SOP Class

DICOM Manager (C-ECHO SCP) provides standard conformance to the DICOM V3.0 verification SOP Class.


4.2.1.4.1.3.1. Dataset Specific Conformance for Verification C-ECHO SCP

Table 40: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Success	C-ECHO command was successful received.

4.2.1.4.2. (Real-World) Activity – FIND as SCP

4.2.1.4.2.1. Description and Sequencing of Activities



The Real World activity associated with the C-FIND-SCP is querying of the local data base based on C-FIND-RQ from the remote DICOM node. DICOM Manager will issue a failure status if it is unable to process the query request.

4.2.1.4.2.2. Accepted Presentation Contexts

The presentation contexts are defined in the next table.

Table 41: Acceptable Presentation Contexts for (Real-World) Activity - FIND As SCP

Presentation Context Table							
Abstract Syntax Transfer Syntax					Extended		
Name	UID	Name List	UID List	Role	Negotiation		
Study Root QR Information	1.2.840.10008.5.1.4.1.2.2.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None		
Model - FIND SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2				

4.2.1.4.2.3. SOP Specific Conformance for Study Root QR Information Model - FIND SOP Class

DICOM Manager provides standard conformance to the DICOM V3.0 Query/Retrieve Service Class as an SCP for the following SOP Class: Study Root Query/Retrieve Information Model - FIND, UID=1.2.840.10008.5.1.4.1.2.2.1.

4.2.1.4.2.3.1. Dataset Specific Conformance for Study Root QR Information Model - FIND SOP Class C-FIND-SCP

Detail regarding the Dataset Specific response behavior will be reported in this section.

IntelliSpace Portal does not support Relational Search, a query that may contain any combination of keys at any level in the hierarchy. Starting at the top level in the Query/Retrieve Information Model, continuing until the Query/Retrieve level specified in the C-FIND request is reached.

All Required (R) and Unique (U) Study, Series and Image level keys for the Study Root Query/Retrieve Information Model are supported.

Unsupported fields will not be returned in the C-FIND response.

Table 42: Requested Query Keys for Study Root Information Model

			Study Root Information M	odel		
Attribute Name	Tag	VR	Type Of Matching	Comment		
Query/Retrieve Level	0008,0052	CS	Single Value			
Q/R Study level						
Accession Number	0008,0050	SH	Single Value			
Modalities in Study	0008,0061	CS	Single Value			
Number of Study Related Instances	0020,1208	IS	Single Value			
Number of Study Related Series	0020,1206	IS	Universal			
Patient ID	0010,0020	LO	Single Value			
Patient's Birth Date	0010,0030	DA	Single Value			
Patient's Birth Time	0010,0032	TM	Single Value, Universal, WildCard			
Patient's Name	0010,0010	PN	Single Value			
Patient's Sex	0010,0040	CS	Single Value, Universal, WildCard			
Referring Physician's Name	0008,0090	PN	Range, Single Value, Universal			
Study Date	0008,0020	DA	Range, Single Value, Universal			
Study Description	0008,1030	LO	Universal			
Study ID	0020,0010	SH	Single Value, Universal, WildCard			
Study Instance UID	0020,000D	UI	Single Value, Universal, WildCard			
Study Time	0008,0030	TM				
			Q/R Series level			
Body Part Examined	0018,0015	CS	Universal			
Manufacturer	0008,0070	LO	Universal			
Modality	0008,0060	CS	Universal			
Number of Series Related Instances	0020,1209	IS	Universal			
Performed Procedure Step Description	0040,0254	LO	Single Value, Universal			
Performed Procedure Step Start Date	0040,0244	DA	Universal			
Performed Procedure Step Start Time	0040,0245	TM	Single Value			
Protocol Name	0018,1030	LO	Single Value			
Series Date	0008,0021	DA	Single Value, Universal			
Series Description	0008,103E	LO	Universal			
Series Instance UID	0020,000E	UI	Single Value, Universal			
Series Number	0020,0011	IS	Universal			

Series Time	0008,0031	TM	Universal	
Study Instance UID	0020,000D	UI	Universal	
Request Attributes Sequence	0040,0275	SQ	Universal	
Q/R Image level				
Columns	0028,0011	US	Universal	
Contrast/Bolus Agent	0018,0010	LO	Universal	
Frame of Reference UID	0020,0052	UI	Single Value	
Image Orientation (Patient)	0020,0037	DS	Universal	
Image Type	0008,0008	CS	Single Value	
Instance Creation Date	0008,0012	DA	Single Value	
Instance Creation Time	0008,0013	TM	Single Value	
Instance Number	0020,0013	IS	Single Value	
KVP	0018,0060	DS	Universal	
Patient Orientation	0020,0020	CS	Universal	
Photometric Interpretation	0028,0004	CS	Single Value	
Pixel Spacing	0028,0030	DS	Universal	
Rows	0028,0010	US	Universal	
Samples per Pixel	0028,0002	US	Single Value	
Series Instance UID	0020,000E	UI	Universal	
Slice Location	0020,1041	DS	Universal	
Slice Thickness	0018,0050	DS	Universal	
SOP Class UID	0008,0016	UI	Single Value	
SOP Instance UID	0008,0018	UI	Universal	
Study Instance UID	0020,000D	UI	Single Value	

C-FIND-CANCEL is supported. However, some C-FIND responses may be forwarded before the C-FIND-CANCEL takes effect.

Table 43: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Matching complete	Matching successful.
Failure	C000	General failure status	Whenever the find operation failed.
Cancel	FE00	Cancel	When receiving a cancel C-FIND request.
Pending	FF00	Pending	For every C-FIND response received.

4.2.1.4.3. (Real-World) Activity – MOVE as SCP

4.2.1.4.3.1. Description and Sequencing of Activities

The Real World activity associated with the C-MOVE command is retrieval of images from the disk and storage of the images to a remote system using a C-STORE command. DICOM Manager will issue a failure status if it is unable to process the transfer request.




Figure 15: (Real World) Activity - Move as SCP.

4.2.1.4.3.2. Accepted Presentation Contexts

The presentation contexts are defined in the next table.

Table 44: Acceptable Presentation Contexts for (Real-World) Activity – MOVE As SCP

Presentation Context Table							
Abstract Syntax Transfer Syntax					Extended		
Name	UID	Name List	UID List	Role	Negotiation		
Study Root QR Information	1.2.840.10008.5.1.4.1.2.2.2	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None		
Model - MOVE SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2				

4.2.1.4.3.3. SOP Specific Conformance for Study Root QR Information Model - MOVE SOP Class

DICOM Manager provides standard conformance to the DICOM V3.0 Query/Retrieve Service Class as an SCP for the following SOP Class: Study Root Query/Retrieve Information Model - MOVE, UID=1.2.840.10008.5.1.4.1.2.2.2. Prioritization of C-MOVE requests is not supported.

4.2.1.4.3.3.1. Dataset Specific Conformance for Study Root QR Information Model - MOVE SOP Class C-MOVE-SCP

DICOM Manager does not support relational C-MOVE requests. All images requested in the C-MOVE will be sent over a single association.

All details regarding the specific conformance, including response behavior of all status codes, both from an application level and communication errors are provided in the following table.

Table 45: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Matching complete	Whenever the move operation succeeded.
Failure	A801	Refused - Move Destination Unknown	Whenever the move destination is unknown to the system.
	C000	Error - Unable to Process	Whenever the move operation failed.
Warning	B000	Sub-operations Complete - One or more Failures	Whenever one of the store operations failed
Pending	FF00	Pending	For every store response received.
Cancel	FE00	Cancel	When receiving a cancel move request.

4.2.1.4.4. (Real-World) Activity – Image Import

4.2.1.4.4.1. Description and Sequencing of Activities

The real world activity associated with the C-STORE operation is the storage of the image in the memory of the system upon which DICOM Manager is running in order to make it available for immediate processing by applications. DICOM Manager will issue a failure status if it is unable to store the image in the memory.




Figure 16: (Real World) Activity - Image Import.

4.2.1.4.4.2. Accepted Presentation Contexts

The presentation contexts are defined in the next table.

Table 46: Acceptable Presentation Contexts for (Real-World) Activity – Image Import

Presentation Context Table						
Abstract Syntax Transfer Syntax				D. I.	Extended	
Name	UID	Name List	UID List	Role	Negotiation	
Computed Radiography Image	1.2.840.10008.5.1.4.1.1.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None	
Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2			

	Presen	tation Context Table			
Abstrac	t Syntax	Transfe	er Syntax	Role	Extended
Name	UID	Name List	UID List	Kole	Negotiation
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
Digital X-Ray Image Storage -	1.2.840.10008.5.1.4.1.1.1.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
For Pres. SOP		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Digital X-Ray Image Storage -	1.2.840.10008.5.1.4.1.1.1.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
For Proc. SOP		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Digital Mammography X-Ray	1.2.840.10008.5.1.4.1.1.1.2	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
Image Storage - Pres. SOP		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Digital Mammography X-Ray	1.2.840.10008.5.1.4.1.1.1.2.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
Image Storage - Proc. SOP		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Digital Intra-oral X-Ray Image	1.2.840.10008.5.1.4.1.1.3	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
Storage - Pres. SOP		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Digital Intra-oral X-Ray Image	1.2.840.10008.5.1.4.1.1.3.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
Storage - Proc. SOP		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Encapsulated PDF Storage	1.2.840.10008.5.1.4.1.1.104.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
		Implicit VR Little Endian	1.2.840.10008.1.2		
Grayscale Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.1	Explicit VR Little Endian Implicit VR Little Endian	1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCP	None
	1 2 040 10000 F 4 4 4 4 4 4 0	Evaligit \/D :ttle Fadica	1 2 940 10009 1 2 1	CCD	None
Color Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.2	Explicit VR Little Endian Implicit VR Little Endian	1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCP	None
_	1.2.840.10008.5.1.4.1.1.11.3	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Pseudo-Color Softcopy Presentation State Storage	1.2.040.10000.3.1.4.1.1.11.3	Implicit VR Little Endian	1.2.840.10008.1.2.1	307	INOHE
Tamana Clara Clarago		mplicit viz citile chaian	1.2.040.10000.1.2		

	Presen	tation Context Table			
Abstrac	t Syntax	Transfe	er Syntax	Role	Extended
Name	UID	Name List	UID List	Kole	Negotiation
Blending Softcopy Presentation State Storage SOP Class	1.2.840.10008.5.1.4.1.1.11.4	Explicit VR Little Endian Implicit VR Little Endian	1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCP	None
X-Ray Angiographic Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.12.1	CT-private-ELE Explicit VR Little Endian Implicit VR Little Endian	1.3.46.670589.33.1.4.1 1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCP	None
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
X-Ray Radiofluoroscopic Image	1.2.840.10008.5.1.4.1.1.12.2	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
Storage SOP Class		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Positron Emission Tomography	1.2.840.10008.5.1.4.1.1.128	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
Image Storage SOP Class		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
CT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.2	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Enhanced CT Image Storage	1.2.840.10008.5.1.4.1.1.2.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
SOP Class		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Nuclear Medicine Image	1.2.840.10008.5.1.4.1.1.20	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2		
MR Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.4	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
RT Image Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
RT Dose Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.2	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		

	Presen	tation Context Table			
Abstrac	t Syntax	Transfe	er Syntax	Role	Extended
Name	UID	Name List	UID List	Role	Negotiation
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
RT Structure Set Storage SOP	1.2.840.10008.5.1.4.1.1.481.3	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Class		Implicit VR Little Endian	1.2.840.10008.1.2		
RT Plan Storage SOP Class	1.2.840.10008.5.1.4.1.1.481.5	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
		Implicit VR Little Endian	1.2.840.10008.1.2		
Raw Data Storage SOP Class	1.2.840.10008.5.1.4.1.1.66	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
		Implicit VR Little Endian	1.2.840.10008.1.2		
Spatial Registration Storage	1.2.840.10008.5.1.4.1.1.66.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Real World Value Mapping	1.2.840.10008.5.1.4.1.1.67	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Storage		Implicit VR Little Endian	1.2.840.10008.1.2		
Secondary Capture Image	1.2.840.10008.5.1.4.1.1.7	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
Storage SOP Class		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		
Multi-frame Single Bit	1.2.840.10008.5.1.4.1.1.7.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Secondary Capture Image Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2		
Multi-frame Grayscale Byte SC	1.2.840.10008.5.1.4.1.1.7.2	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Image Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2		
Multi-frame Grayscale Word SC	1.2.840.10008.5.1.4.1.1.7.3	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Image Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2		
Multi-frame True Color	1.2.840.10008.5.1.4.1.1.7.4	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Secondary Capture Image Storage		Implicit VR Little Endian	1.2.840.10008.1.2		
Key Object Selection Document	1.2.840.10008.5.1.4.1.1.88.59	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
		Implicit VR Little Endian	1.2.840.10008.1.2		
General ECG Waveform	1.2.840.10008.5.1.4.1.1.9.1.2	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCP	None
Storage SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2		
Philips Private ViewForum 3D	1.3.46.670589.5.0.1.1	CT-private-ELE	1.3.46.670589.33.1.4.1	SCP	None
Volume New Storage		Explicit VR Little Endian	1.2.840.10008.1.2.1		
		Implicit VR Little Endian	1.2.840.10008.1.2		
		JPEG Lossless, Non- Hierarchical, FOP (Process 14)	1.2.840.10008.1.2.4.70		

Note: The default supported Transfer Syntax is ILE. All Transfer Syntaxes are configurable in LAN Config, in the order Private-ELE, JPEG, ELE, and ILE. CT-private-ELE has preference over ELE, ILE and JPEG. For all SOP classes without pixel data the JPEG transfer syntax will not supported.

4.2.1.4.4.3. SOP Specific Conformance for Storage SOP Classes

This section and sub-section includes the manufacturer SOP and Dataset specific information as well the status codes and their corresponding behavior.

DICOM Manager provides standard conformance to the DICOM V3.0 Storage Service Class as a SCP. DICOM Manager conforms to the SOPs of the Storage Service Class at Level 2 (Full). In case of a successful C-STORE, the stored image may be accessed by the processing applications.

4.2.1.4.4.3.1. Dataset Specific Conformance for C-STORE-RSP

Table 47: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Successful stored	Whenever the store operation succeeded.
Failure	Cxxx	Failed	Whenever the store operation failed.

4.2.2. Print Manager

Detail of this specific Application Entity is specified in this section.

4.2.2.1. **SOP Classes**

This Application Entity provides Standard Conformance to the following SOP Classes.

Table 48: SOP Classes for Print Manager

SOP Class Name	SOP Class UID	SCU	SCP
Basic Color Print Management Meta SOP Class	1.2.840.10008.5.1.1.18	Yes	No
>Basic Film Session SOP Class	1.2.840.10008.5.1.1.1	Yes	No
Basic Grayscale Print Management Meta SOP Class	1.2.840.10008.5.1.1.9	Yes	No
>Basic Film Session SOP Class	1.2.840.10008.5.1.1.1	Yes	No

Note: Any SOP specific behavior is documented later in the conformance statement in the applicable SOP specific conformance section.

4.2.2.2. Association Policies

Each AE specification contains a description of the general association establishment and acceptance policies of the AE.

4.2.2.2.1. General

The maximum PDU Size that the Print-Manager will use is configurable, with a minimum of 2 Kbytes.

Table 49: DICOM Application Context

Description	Value
Application Context Name	1.2.840.10008.3.1.1.1

4.2.2.2.2. Number of Associations

The number of simultaneous associations that an Application Entity may support as a Initiator or Acceptor is specified.

Print-Manager can have only one open connection at a given time.

Table 50: Number of associations as an Association Initiator for this AE

Description	Value
Maximum number of simultaneous associations	1

4.2.2.2.3. Asynchronous Nature

The implementation supports negotiation of multiple outstanding transactions, along with the maximum number of outstanding transactions supported.

Print-Manager will only allow a single outstanding operation on an association.

Table 51: Asynchronous nature as an Association Initiator for this AE

Description	Value
Maximum number of outstanding asynchronous transactions	1

4.2.2.2.4. Implementation Identifying Information

The value supplied for Implementation Class UID and version name are documented here.

Table 52: DICOM Implementation Class and Version for Print Manager

Implementation Class UID	1.3.46.670589.33.1.1
Implementation Version Name	BRCONN_4.0

4.2.2.2.5. Communication Failure Handling

Not applicable.

4.2.2.3. Association Initiation Policy

4.2.2.3.1. (Real-World) Activity - Print Management as SCU

4.2.2.3.1.1. Description and Sequencing of Activities

After selecting the print destination (out of choice list of configured printers) and some print parameters (depending on the configuration and the selected printer; these values can be configured too), Print-Manager initiates an association when a print job is submitted to a DICOM printer (when the user clicks on the print button in the film view). The association is left open after the job is completed for a configurable time-out (so that if there are other jobs to the same printer, they will be done on the same association). Jobs to different printers are performed simultaneously.




Figure 17: (Real World) Activity - Print Manager Initiates

Normally, when the job is completed and there are no other jobs to the same printer, the Print manager does close the association with an A-RELEASE request. If a TCP/IP connection timeout occurs, then the association is closed. In this case, a new association is set up when needed.




Figure 18: (Real World) Activity - Print Management as SCU

4.2.2.3.1.2. Proposed Presentation Contexts

The presentation contexts are defined in the next table.

Table 53: Proposed Presentation Contexts for (Real-World) Activity - Print Management As SCU

Presentation Context Table								
Abstrac	t Syntax	Transfer S		Extended				
Name	UID	Name List	UID List	Role	Negotiation			
Basic Color Print Management Meta SOP Class	1.2.840.10008.5.1.1.18			SCU	None			
>Basic Film Session SOP Class	1.2.840.10008.5.1.1.1	Explicit VR Little Endian Implicit VR Little Endian	1.2.840.10008.1.2.1 1.2.840.10008.1.2	SCU	None			
Basic Grayscale Print Management Meta SOP Class	1.2.840.10008.5.1.1.9			SCU	None			
>Basic Film Session SOP Class	1.2.840.10008.5.1.1.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			

Presentation Context Table								
Abstrac	t Syntax	Transfer S	Syntax	Data	Extended			
Name	UID	Name List	UID List	Role	Negotiation			
		Implicit VR Little Endian	1.2.840.10008.1.2					
Basic Color Print Management Meta SOP Class	1.2.840.10008.5.1.1.18			SCU	None			
>Printer SOP Class	1.2.840.10008.5.1.1.16	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
		Implicit VR Little Endian	1.2.840.10008.1.2					
Basic Grayscale Print Management Meta SOP Class	1.2.840.10008.5.1.1.9			SCU	None			
>Printer SOP Class	1.2.840.10008.5.1.1.16	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
		Implicit VR Little Endian	1.2.840.10008.1.2					
>Basic Film Box SOP Class	1.2.840.10008.5.1.1.2	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
		Implicit VR Little Endian	1.2.840.10008.1.2					
Basic Color Print Management Meta SOP Class	1.2.840.10008.5.1.1.18			SCU	None			
>Basic Film Box SOP Class	1.2.840.10008.5.1.1.2	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
		Implicit VR Little Endian	1.2.840.10008.1.2					
Basic Grayscale Print Management Meta SOP Class	1.2.840.10008.5.1.1.9			SCU	None			
>Basic Grayscale Image Box	1.2.840.10008.5.1.1.4	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
SOP Class		Implicit VR Little Endian	1.2.840.10008.1.2					
Basic Color Print Management Meta SOP Class	1.2.840.10008.5.1.1.18			SCU	None			
>Basic Color Image Box SOP	1.2.840.10008.5.1.1.4.1	Explicit VR Little Endian	1.2.840.10008.1.2.1	SCU	None			
Class		Implicit VR Little Endian	1.2.840.10008.1.2					

Note: The only supported defaults Transfer Syntaxes for printing are ELE and ILE.

This section specifies each IOD created (including private IOD's).

Abbreviations used in the Module table for the column "Presence of Value" are:

ALWAYS The attribute is always present with a value

EMPTY The attribute is always present without any value (attribute sent zero length)

VNAP The attribute is always present and its Value is Not Always Present

(attribute sent zero length if no value is present)

ANAP The attribute is present under specified condition – if present then it will always have a value VNAPCV The attribute is present under specified condition – if present then its Value is Not Always Present

(attribute sent zero length if condition applies and no value is present)

ANAPEV The attribute is present under specified condition – if present then it will not have any value

The abbreviations used in the Module table for the column "Source" are:

AUTO The attribute value is generated automatically

CONFIG The attribute value source is a configurable parameter
COPY The attribute value source is another SOP instance
FIXED The attribute value is hard-coded in the application
IMPLICIT The attribute value source is a user-implicit setting

MPPS The attribute value is the same as that use for Modality Performed Procedure Step

MWL The attribute value source is a Modality Worklist USER The attribute value source is explicit user input

4.2.2.3.1.3. SOP Specific Conformance for Basic Film Session SOP Class of the Basic Color Print Management Meta SOP Class

This section and sub-section includes the manufacturer SOP and Dataset specific information as well the status codes and their corresponding behavior.

The Printer process conforms to the Basic Film Session SOP Class. The following DIMSE service elements are supported: N-CREATE, N-DELETE.

4.2.2.3.1.3.1. Dataset Specific Conformance for Basic Film Session SOP Class N-CREATE-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

Table 54: Basic Film Session Presentation Module

Attribute Name	Tag	VR	Value	Presence of Value	Source	Comment
Number of Copies	2000,0010	IS		ALWAYS	CONFIG	Value between 1-100
Print Priority	2000,0020	CS	AUTO, HIGH, LOW, MED	ANAP	USER	
Medium Type	2000,0030	CS	BLUE FILM, CLEAR FILM, PAPER	ALWAYS	CONFIG, USER	
Film Destination	2000,0040	CS	MAGAZINE, PROCESSOR	ALWAYS	CONFIG	

This part of the section includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 55: Status Response

Service Status	Error Code Further Meaning		Behavior
Success	0000	Film Session successfully created	The print job continues.
Warning	B600	Memory Allocation not supported	The print job continues and the warning is logged.

4.2.2.3.1.3.2. Dataset Specific Conformance for Basic Film Session SOP Class N-DELETE-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

This part of the section includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 56: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Film Session successfully created	The SCP has completed the operation successfully.
Other than Success	<>0000	Other status	On any other status then success, the job remains in the queue manager, with status failed.

4.2.2.3.1.4. SOP Specific Conformance for Basic Film Session SOP Class of the Basic Grayscale Print Management Meta SOP Class

The Printer process conforms to the Basic Film Session SOP Class. The following DIMSE service element is supported: N-CREATE, N-DELETE.

4.2.2.3.1.4.1. Dataset Specific Conformance for Basic Film Session SOP Class N-CREATE-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

Table 57: Basic Film Session Presentation Module

Attribute Name	Tag	VR	Value	Presence of Value	Source	Comment
Number of Copies	2000,0010	IS		ALWAYS	CONFIG, USER	-
Print Priority	2000,0020	CS	AUTO, HIGH, LOW, MED	ALWAYS	CONFIG, USER	-
Medium Type	2000,0030	CS	BLUE FILM, CLEAR FILM, PAPER	ALWAYS	USER	-
Film Destination	2000,0040	CS	MAGAZINE, PROCESSOR	ANAP	USER	-

This part of the section includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 58: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Film Session successfully created	The print job continues.
Warning	B600	Memory Allocation not supported	The print job continues and the warning is logged.

4.2.2.3.1.4.2. Dataset Specific Conformance for Basic Film Session SOP Class N-DELETE-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

This part of the section includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 59: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Film Session successfully created	The SCP has completed the operation successfully.
Other than Success	<>0000	Other status	On any other status then success, the job remains in the queue manager, with status failed.

4.2.2.3.1.5. SOP Specific Conformance for Printer SOP Class of the Basic Color Print Management Meta SOP Class Not Applicable, Printer SOP Class is not supported.

4.2.2.3.1.5.1. Dataset Specific Conformance for Printer SOP Class N-EVENT-REPORT-SCP

Not Applicable, Printer SOP Class is not supported.

4.2.2.3.1.6. SOP Specific Conformance for Printer SOP Class of the Basic Grayscale Print Management Meta SOP Class Not Applicable, Printer SOP Class is not supported.

4.2.2.3.1.6.1. Dataset Specific Conformance for Printer SOP Class N-EVENT-REPORT-SCP

Not applicable, Printer SOP Class is not supported.

4.2.2.3.1.7. SOP Specific Conformance for Basic Film Box SOP Class of the Basic Grayscale Print Management Meta SOP Class

This section and sub-section includes the manufacturer SOP and Dataset specific information as well the status codes and their corresponding behavior.

The Printer process conforms to the Basic Film Box Sop Class. The following DIMSE service elements are supported: N-CREATE, N-ACTION, N-DELETE.

4.2.2.3.1.7.1. Dataset Specific Conformance for Basic Film Box SOP Class N-CREATE-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

Table 60: Basic Film Box Presentation Module

Attribute Name	Tag	VR	Value	Presence of Value	Source	Comment
Image Display Format	2010,0010	ST	STANDARD\1,1	ALWAYS	CONFIG	-
Film Orientation	2010,0040	CS	LANDSCAPE, PORTRAIT	ALWAYS	CONFIG, USER	-
Film Size ID	2010,0050	CS		ALWAYS	CONFIG, USER	As in Printer Configuration file.
Magnification Type	2010,0060	CS		ALWAYS	CONFIG	As in Printer Configuration file.
Min Density	2010,0120	US		ALWAYS	CONFIG	As in Printer Configuration file.
Max Density	2010,0130	US		ALWAYS	CONFIG	As in Printer Configuration file.
Trim	2010,0140	CS	NO, YES	ALWAYS	CONFIG, USER	-
Configuration Information	2010,0150	ST		ALWAYS	CONFIG	As in Printer Configuration file.

Table 61: Basic Film Box Relationship Module

Attribute Name	Tag	VR	Value	Presence of Value	Source	Comment
Referenced Film Session Sequence	2010,0500	SQ		ALWAYS	AUTO	
>Referenced SOP Class UID	0008,1150	UI		ALWAYS	AUTO	UID of Parent Film Session.
>Referenced SOP Instance UID	0008,1155	UI		ALWAYS	AUTO	-

Table 62: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Film Box successfully created	The SCP has completed the operation successfully.
Warning	B605	Requested Min Density or Max Density outside of Printer's operating Range	The print job continues and the warning is logged.
	0107	Attribute list error	The print job continues and the warning is logged.
	0116	Attribute out of range	The print job continues and the warning is logged.
	B000 - B007		The print job continues and the warning is logged.
Failure	C616	There is an existing Film Box that has not been printed	The print job is marked as failed and the reason is logged.

4.2.2.3.1.7.2. Dataset Specific Conformance for Basic Film Box SOP Class N-ACTION-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

This part of the section includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 63: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Film accepted for printing	The print job continues.
Warning	B603	Film Box SOP Instance Hierarchy does not contain Image Box SOP Instances	The print job continues and the warning is logged and reported to the user.
	B604	Image Size is larger than Image Box Size - The Image has been demagnified	The print job continues and the warning is logged and reported to the user.
	B609	Image Size is larger than Image Box Size - The Image has been cropped to fit	The print job continues and the warning is logged and reported to the user.
	B60A	Image Size or combined Print Image Size is larger than Image Box Size - The Image or combined Print Image has been decimated to fit	The print job continues and the warning is logged and reported to the user.
	0107	Attribute list error	The print job continues and the warning is logged.
	0116	Attribute out of range	The print job continues and the warning is logged.
	B000 - B007		The print job continues and the warning is logged.
Failure	C602	Unable to create Print Job SOP Instance - Print Queue is full	The print job is marked as failed and the reason is logged and reported to the user.
	C603	Image Size is larger than Image Box Size	The print job is marked as failed and the reason is logged and reported to the user.
	C613	Combined Print Image Size is larger than Image Box Size	The print job is marked as failed and the reason is logged and reported to the user.
	<>0000	Other status	On any other status then success, the job remains in the queue manager, with status failed.

4.2.2.3.1.7.3. Dataset Specific Conformance for Basic Film Box SOP Class N-DELETE-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

Table 64: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Film Session successfully created	The SCP has completed the operation successfully.
	0107	Attribute list error	The print job continues and the warning is logged.
	0116	Attribute out of range	The print job continues and the warning is logged.
	B000 - B007		The print job continues and the warning is logged.
Other than Success	<>0000	Other status	On any other status then success, the job remains in the queue manager, with status failed.

4.2.2.3.1.8. SOP Specific Conformance for Basic Film Box SOP Class of the Basic Color Print Management Meta SOP Class

This section and sub-section includes the manufacturer SOP and Dataset specific information as well the status codes and their corresponding behavior.

The Printer process conforms to the Basic Film Box Sop Class. The following DIMSE service elements are supported: N-CREATE, N-ACTION, N-DELETE.

4.2.2.3.1.8.1. Dataset Specific Conformance for Basic Film Box SOP Class N-CREATE-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

Table 65: Basic Film Box Presentation Module

Attribute Name	Tag	VR	Value	Presence of Value	Source	Comment
Image Display Format	2010,0010	ST	STANDARD\1,1	ALWAYS	CONFIG	-
Film Orientation	2010,0040	CS	LANDSCAPE, PORTRAIT	ALWAYS	CONFIG, USER	-
Film Size ID	2010,0050	CS		ALWAYS	CONFIG, USER	As in printer configuration file.
Magnification Type	2010,0060	CS		ALWAYS	CONFIG	As in printer configuration file.
Min Density	2010,0120	US		ALWAYS	CONFIG	As in printer configuration file.
Max Density	2010,0130	US		ALWAYS	CONFIG	As in printer configuration file.
Trim	2010,0140	CS	NO, YES	ALWAYS	CONFIG, USER	
Configuration Information	2010,0150	ST		ALWAYS	CONFIG	As in printer configuration file.

Table 66: Basic Film Box Relationship Module

Attribute Name	Tag	VR	Value	Presence of Value	Source	Comment
Referenced Film Session Sequence	2010,0500	SQ		ALWAYS	AUTO	-
>Referenced SOP Class UID	0008,1150	UI		ALWAYS	AUTO	UID of Parent Film Session.
>Referenced SOP Instance UID	0008,1155	UI		ALWAYS	AUTO	-

This part of the section includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 67: Status Response

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Film Box successfully created	The SCP has completed the operation successfully.
Warning	0107	Attribute list error	The print job continues and the warning is logged.
	0116	Attributes out of range	The print job continues and the warning is logged.
	B000 - B007		The print job continues and the warning is logged.
	B605		The print job continues and the warning is logged.
Failure	C616		The print job is marked as failed and the reason is logged.

4.2.2.3.1.8.2. Dataset Specific Conformance for Basic Film Box SOP Class N-ACTION-SCU

Detail regarding the Dataset Specific response behavior will be reported in this section.

Table 68: DICOM Command Response Status Handling Behavior for Basic Film Box N-Action

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Film accepted for printing	The print job continues.
Warning	0107	Attribute list error	The print job continues and the warning is logged.
	0116	Attribute out of range	The print job continues and the warning is logged.
	B000 - B007		The print job continues and the warning is logged.
	B603	Film Box SOP Instance Hierarchy does not contain Image Box SOP Instances	The print job continues and the warning is logged and reported to the user.
	B604	Image Size is larger than Image Box Size - The Image has been demagnified	The print job continues and the warning is logged and reported to the user.
	B609	Image Size is larger than Image Box Size - The Image has been cropped to fit	The print job continues and the warning is logged and reported to the user.
	B60A	Image Size or combined Print Image Size is larger than Image Box Size - The Image or combined Print Image has been decimated to fit	The print job continues and the warning is logged and reported to the user.
Failure	<> 0000	Any other status then success	The print job is marked as failed, the reason is logged and reported to the user.

4.2.2.3.1.8.3. Dataset Specific Conformance for Basic Film Box SOP Class N-DELETE-SCU

This part of the section includes the dataset specific behavior, i.e. error codes, error and exception handling, time-outs, etc.

Table 69: Status Response

Service Status	Error Code	Further Meaning	Behavior		
Success	0000	Film Session successfully created	The SCP has completed the operation successfully		
Warning	0107	Attribute list error	The print job continues and the warning is logged.		
	0116	Attribute out of range	The print job continues and the warning is logged.		
	B000 - B007		The print job continues and the warning is logged.		
Other than Success	<>0000	Any other status then success	The job remains in the queue manager, with status failed		

4.2.2.3.1.9. SOP Specific Conformance for Basic Grayscale Image Box SOP Class of the Basic Grayscale Print Management Meta SOP Class

The Printer process conforms to the Basic Grayscale Image Box Sop Class. The following DIMSE service element is supported: N-SET.

4.2.2.3.1.9.1. Dataset Specific Conformance for Basic Grayscale Image Box SOP Class N-SET-SCU

Table 70: Image Box Pixel Presentation Module

Attribute Name	Tag	VR	Value	Presence of Value	Source	Comment
Image Box Position	2020,0010	US	1	ALWAYS	AUTO	
Basic Grayscale Image Sequence	2020,0110	SQ		ALWAYS	AUTO	
>Samples per Pixel	0028,0002	US	1, 3	ALWAYS	AUTO	
>Photometric Interpretation	0028,0004	CS	MONOCHROME2, RGB	ALWAYS	AUTO	
>Rows	0028,0010	US		ALWAYS	AUTO	As in Printer configuration file.

>Columns	0028,0011	US		ALWAYS	AUTO	As in Printer configuration file.
>Pixel Aspect Ratio	0028,0034	IS		ALWAYS	AUTO	Must be present if not 1/1.
>Bits Allocated	0028,0100	US	8	ALWAYS	AUTO	
>Bits Stored	0028,0101	US	8	ALWAYS	AUTO	
>High Bit	0028,0102	US	7	ALWAYS	AUTO	
>Pixel Representation	0028,0103	US	0	ALWAYS	AUTO	
>Pixel Data	7FE0,0010	O W/ OB		ALWAYS	AUTO	

Table 71: DICOM Command Response Status Handling Behavior for Basic Grayscale Image Box N-SET.

Service Status	Error Code	Further Meaning	Behavior
Success	0000		The print job continues
	0107		The print job is continues and the warning is logged.
	0116		The print job is continues and the warning is logged.
Warning	B000 - B007		The print job is continues and the warning is logged.
vvairing	B604		The print job continues, the warning is logged and reported to the user.
	B605		The print job continues, the warning is logged and reported to the user.
	B609		The print job continues, the warning is logged and reported to the user.
	B60A		The print job continues, the warning is logged and reported to the user.
Error	<xxxx></xxxx>	All other error code not found in this list	The print job is marked as failed an the reason is logged and reported to the user.

4.2.2.3.1.10. SOP Specific Conformance for Basic Color Image Box SOP Class of the Basic Color Print Management Meta SOP Class

The Printer process conforms to the Color Image Box Sop Class. The following DIMSE service element is supported: N-SET.

4.2.2.3.1.10.1. Dataset Specific Conformance for Basic Color Image Box SOP Class N-SET-SCU

Details regarding the Dataset Specific response behavior will be reported in this section.

Table 72: Image Box Pixel Presentation Module

Attribute Name	Tag	VR	Value	Presence of Value	Source	Comment
Image Box Position	2020,0010	US	1	ALWAYS	AUTO	-
Basic Color Image Sequence	2020,0111	SQ		ALWAYS	AUTO	-
>Samples per Pixel	0028,0002	US		ALWAYS	AUTO	-
>Photometric Interpretation	0028,0004	CS	RGB	ALWAYS	AUTO	-
>Planar Configuration	0028,0006	US		ALWAYS	AUTO	-
>Rows	0028,0010	US		ALWAYS	AUTO	As in printer configuration file.
>Columns	0028,0011	US		ALWAYS	AUTO	As in printer configuration file.
>Pixel Aspect Ratio	0028,0034	IS		ALWAYS	AUTO	Must be present if not 1/1.
>Bits Allocated	0028,0100	US	8	ALWAYS	AUTO	-
>Bits Stored	0028,0101	US	8	ALWAYS	AUTO	-
>High Bit	0028,0102	US	7	ALWAYS	AUTO	-
>Pixel Representation	0028,0103	US		ALWAYS	AUTO	-
>Pixel Data	7FE0,0010	O W/ OB		ALWAYS	AUTO	

Table 73: DICOM Command Response Status Handling Behavior for Basic Color Image Box N-SET

Service Status	Error Code	Further Meaning	Behavior
Success	0000	Image successfully stored in Image Box	The print job continues
Warning	0107	Attribute list error	The print job continues and the warning is logged.
	0116	Attribute out of range	The print job continues and the warning is logged.
	B000 - B007		The print job continues and the warning is logged.
	B604	Image Size is larger than Image Box Size - The Image has been demagnified	The print job continues and the warning is logged and reported to the user.
	B605	Requested Min Density or Max Density outside of Printer's operating Range	The print job continues and the warning is logged and reported to the user.
	B609	Image Size is larger than Image Box Size - The Image has been cropped to fit	The print job continues and the warning is logged and reported to the user.
	B60A	Image Size or combined Print Image Size is larger than Image Box Size - The Image or combined Print Image has been decimated to fit	The print job continues and the warning is logged and reported to the user.
Error	<xxxx></xxxx>	All other errors than found in this list	The print job is marked as failed an the reason is logged and reported to the user.

4.2.2.4. Association Acceptance Policy

Not applicable, Print Manager AE never accepts an association.

Document Number: PIIOffc.0000142

4.3. Network Interfaces

4.3.1. Physical Network Interfaces

The System provides only DICOM V3.0 TCP/IP Network Communication Support as defined in PS 3.8 of the DICOM standard.

Philips IntelliSpace Portal inherits its TCP/IP stack from Windows XP (i.e. the operating system platform).

Philips IntelliSpace Portal supports a single network interface Ethernet ISO 8802-3.

With standard supported physical medium include:

IEEE 802.3-1995, 10BASE-T

IEEE 802.3-1995, 100BASE-TX (Fast Ethernet)

IEEE 802.3, 1000BASE-X (Fiber Optic Gigabit Ethernet).

4.3.2. Additional Protocols

Additional protocols such as used for network management are not applicable.

4.4. Configuration

Any implementation's DICOM conformance may be dependent upon configuration, which takes place at the time of installation. Issues concerning configuration are addressed in this section.

4.4.1. AE Title/Presentation Address Mapping

The Philips IntelliSpace Portal system is configured by means of a configuration program. This program is accessible at start-up of the Philips IntelliSpace Portal system. It is password protected and intended to be used by the administrator onsite or Philips Customer Support Engineers only.

Per configuration in LAN Config Tool, the system allows to accept associations from a range of IP addresses (not to check source IP or Calling AE Title). With incoming association requests the system allows acceptance of a range of defined IP addresses which is configurable in the LAN Config application. The system is not IP or AE title sensitive.

4.4.1.1. Local AE Titles

The local AE title mapping and configuration are specified as:

Table 74: AE Title configuration table

Application Entity	Default AE Title	Default TCP/IP Port
DICOM Manager	SCU: <system ae="" title="">, SCP: <system ae="" title=""> or <local folder=""></local></system></system>	104 (configurable)
Print Manager	<system ae="" title=""></system>	

4.4.1.2. Remote AE Title/Presentation Address Mapping

Remote AE Title, IP-Address, Port-number, supported DICOM Services and supported Transfer Syntaxes are freely configurable.

4.4.2. Parameters

The specification of important operational parameters, their default value and range (if configurable) are specified here.

Table 75: Configuration General Parameters Table

Parameter	Configurable	Default Value
Basic Parameters		
Network - Computer Name	Yes	<hostname> Set by installation</hostname>
Network - IP	Yes	(0.0.0.0)
Network - Gateway	Yes	(0.0.0.0)
System Port	Yes	104
System - AE Title	Yes	DATABASE
Local - Auto Delete Enabled	Yes	Checked
Maximum PDU size as SCU	Yes	65536
Maximum PDU size as SCP	No	16352
Transfer Syntax support, P- ELE, JPEG, ELE, ILE, There is a configuration option to turn off /on, P-ELE, JPEG, ELE, ILE	Yes	ELE, ILE (non-Philips device)Private ELE, JPEG, ELE, ILE (for latest versions of Philips devices i.e. 4.x)
Storage / Retrieve Timeout	Yes	300 seconds
ARTIM timeout	Yes	300 seconds
Max association number	No	50
Advanced Parameters		
Local - Auto Delete - Execute Only Once	Yes	UnChecked
Local - Auto Delete - Days to keep study	Yes	14
Local - AutoDelete - Mbytes to Reserve	Yes	11264
Auto Import - Enable	Yes	Unchecked
Auto Import - Input Folder Name	Yes	No Value
Auto Import - Failed Folder Name	Yes	No Value
Auto import - Import Type	Yes	DICOM
Auto Import - PollingIntervalInSeconds	Yes	60
Verify Service Timeout in Seconds	Yes	60
Query Service Timeout in Seconds	Yes	60
Store Service Timeout in Seconds	Yes	300
Storage Commitment Service Timeout in Seconds	Yes	300
Retrieve Service Timeout in Seconds	Yes	300
Print Service Timeout in Seconds	Yes	300

Table 76: Configuration Local Parameters table

Parameter	Configurable	Default Value
Advanced Parameter		
Local - Auto Delete - Execute Only Once	Yes	Unchecked
Local - Auto Delete - Days to keep study	Yes	1
Local - AutoDelete - Mbytes to Reserve	Yes	12207
Read Only Folder	Yes	Unchecked
Auto Import - Enable	Yes	Unchecked
Auto Import - Input Folder Name	Yes	No Value
Auto Import - Failed Folder Name	Yes	No Value
Auto Import - Import Type	Yes	DICOM
Auto Import - PollingIntervalInSeconds	Yes	60

Table 77: Configuration Remote Parameters Table

Parameter	Configurable	Default Value
Advanced Parameter - Query		
Association Timeout In Seconds	Yes	300
Lowest Support Level	Yes	Image
Query Response Size	Yes	100
Advanced Parameter - Store		
Association Timeout In Seconds	Yes	120
Advanced Parameter - Retrieve		
Association Timeout In Seconds	Yes	0
Advanced Parameter - Storage Commitment		
Association Timeout In Seconds	Yes	120

Table 78: Configuration General Print Parameters Table

Parameter	Configurable	Default Value
Advanced Parameter		
Association Timeout In Seconds	Yes	150

Printers are configurable by a selection of the default printer types. Every printer type has a fixed configuration, but can be extended with new ones. The default printer settings are defined in the printer configuration file.

5. Media Interchange

5.1. Implementation model

The implementation model identifies the DICOM Application Entities for Media in specific implementation and relates the Application Entities to Real-World Activities.

5.1.1. Application Data Flow Diagram

As part of the implementation model, an application data flow diagram is included. The next Figure shows the media interchange application data flow as a functional overview of the Media AE for DICOM CD and DVD.




Figure 19: Media Interchange Application Data Flow Diagram.

The Media AE acts as a FSR, for CD-R and DVD, when reading the directory of the medium. The Media AE acts as a FSC for CD-R and DVD, when writing the selected images in a patient folder onto the medium.

5.1.2. Functional Definitions of AE's

The Philips IntelliSpace Portal can Create and Read CD/DVD.

The Media AE in a Philips IntelliSpace Portal supports the following functions for CD and DVD as FSR:

- Read the DICOMDIR File from the medium (representing the directory of the DICOM File(s) as recorded on the medium). This
 information may be displayed as an ordered list of icon images and, if present, with pertinent identifying information (patient
 name, etc.).
- Read the selected image from the medium and display it on the monitor of the workstation. This information is displayed as an ordered list of frames of the selected image or as a dynamic review of the selected image.

And for CD and DVD as FSC:

- Initialize the medium.
- Write a DICOM File-set onto the medium.
- Create a DICOMDIR File.
- Extend the DICOM File-set and update the DICOMDIR File accordingly (DICOM Media Storage Service Class).

5.1.3. Sequencing of Real World Activities

A Real World Activity of the Media AE is: The user selects a set of object to write these to the CD/DVD. Then the CD /DVD will be created with the selected objects. Once the CD/DVD has been created, the user can read this CD/DVD on the Philips IntelliSpace Portal or for transport to another device for reading.




Figure 20: (Real World) Activity - Media.

Another Real World Activity of the Media AE is: A CD/DVD from another system Philips IntelliSpace Portal or previously created CD/DVD can be read by the Philips IntelliSpace Portal. The IntelliSpace Portal cannot append (FSU) to this created CD/DVD.

After data is written to DVD, the DVD is finalized; the finalized DVD can now be read on every DVD reader.

5.2. AE Specifications

This section in the DICOM Conformance Statement specifies a set of Media Application Entities.

5.2.1. Media AE Media - Specification

The supported Application Profiles, their Roles and the Service Class options, all defined in DICOM terminology, are listed in the following table.

For reading and writing the media AE provides standard conformance to:

- DICOM media Storage Service and File Format ([DICOM] PS 3.10);
- Media Storage Application Profiles ([DICOM] PS 3.11); and
- Media Formats and Physical Media for Media Interchange ([DICOM] PS 3.12) for Reading (FSR) and Writing (FSC).

Philips IntelliSpace Portal does not support multi-session writes to CD/DVD's.

Supported media:

- CD: CD-R and CD-RW with the profile STD-GEN-CD.
- DVD: DVD-R, DVD+R, DVD-RW, DVD+RW and DVD-RAM with the profile: STD-GEN-DVD-JPEG as FSR.

The supported Application Profiles, their roles and the Service Class (SC) options, all defined in DICOM terminology, are listed in the next Table.

Supported Application Profile	Identifier	Real-World Activities	Roles
CT/MR Studies on CD-R	STD-CTMR-CD	Create File-set	FSC
		Read File-set	FSR
		Display Directory	DD
General Purpose CD-R Interchange	STD-GEN-CD	Create File-set	FSC
		Read File-set	FSR
		Display Directory	DD
CT/MR Studies on DVD Media	STD-CTMR-DVD	Create File-set	FSC:

Table 79: AE Media AE related Application Profiles, RWA activities and roles

Supported Application Profile	Identifier	Real-World Activities	Roles
		Read File-set	FSR
		Display Directory	DD
General Purpose DVD Interchange with JPEG	STD-GEN-DVD-JPEG	Create File-set	FSC
		Read File-set	FSR
		Display Directory	DD

5.2.1.1. File Meta Information for the Media AE

This section contains the values of the file Meta Information that pertain to the Application Entity (see PS 3.10). These are:

- Source Application Entity Title,
- Private Information Creator UID,
- Private Information.

The Application Entity title is registered into the DICOM File Meta Information header and is supported by the CD/DVD-Writer (CD/DVD write option) acting as a FSC.

Table 80: File Meta Information for the Media AE

Implementation Class UID	1.3.46.670589.33.1.1
Implementation Version Name	BRCONN_4.0

5.2.1.2. Real-World Activities

The AE specification contains a description of the Real-World Activities, which invoke the particular AE.

5.2.1.2.1. RWA - Read File-set

When an image transfer from CD or DVD is initiated then the Media AE acts as an FSR using the interchange option to import SOP Instances from the CD or DVD medium.

5.2.1.2.1.1. Media Storage Application Profile

The media AE supports the RWA Read File-set for the STD-CT/MR studies on CD, the STD-GEN-CD, the General Purpose DVD Interchange with JPEG and CT/MR Studies on DVD Media application profiles.

5.2.1.2.1.1.1. Options

Not applicable.

5.2.1.2.2. RWA - Create File-set

When an image transfer to CD/DVD is initiated then the Media AE acts as an FSC using the interchange option to export SOP Instances from the local database to a CD/DVD medium.

5.2.1.2.2.1. Media Storage Application Profile

As depicted in the table in section 5.2.1, the Media AE supports the RWA Write Images for the STD-CTMR-CD, STD-GEN-CD and the STD-GEN-DVD-JPEG Application Profile.

The DICOMDIR file will be extended when new images are written. In case some attributes are not present in an image but are specified as mandatory in the DICOMDIR definition in DICOM Media, a generated value will be filled in.

Implementation remarks and restrictions:

When writing the DICOMDIR records, key values are generated when no value of the corresponding attribute is supplied, according to the following tables.

Table 81: Generated Keys.

Key	Tag	Generated Value
Study Keys		
Study Date	(0008,0020)	Date on which this Study was created.
Study Time	(0008,0030)	Time on which this Study was created.
Series Keys		
Series Number	(0020,0011)	1
Image Keys		
Instance Number	(0020,0013)	1 (if empty)

The data selected to write to the media must fit on the currently inserted media. If it does not fit, an error is generated and it is up to the operator to re-select a smaller amount of data to be written to the media. The system will not request additional media or write across multiple media.

Table 82: Supported attributes in the DICOMDIR.

DICOM Tag	Description
0002,0000	Group 0002 Length
0002,0001	File Meta Information Version
0002,0002	UI Media Storage Sop Class UID
0002,0003	UI Media Storage Sop Instance UID
0002,0010	UI Transfer Syntax UID
0002,0012	UI Implementation Class UID
0002,0013	Implementation Version Name
0002,0016	Source Application Entity Title
File Set and Directory Information	
0004,1130	File Set ID
0004,1200	First Directory Record Offset
0004,1202	Last Directory Record Offset
0004,1212	File Set Consistency Flag
0004,1220	Directory Record Sequence
Patient level	
0004,1400	Offset Of The Next Dir Record
0004,1410	Record In Use Flag
0004,1420	Offset of Referenced Lower-Level Directory Entity
0004,1430	Directory Record Type
0008,0005	Specific Character Set
0010,0010	Patient's Name
0010,0020	Patient ID
Study level	
0004,1400	Offset Of The Next Dir Record
0004,1410	Record In Use Flag
0004,1420	Offset Of Ref Lower Level Dir Ent
0004,1430	Directory Record Type
0008,0005	Specific Character Set
0008,0020	Study Date
0008,0030	Study Time
0008,0050	Accession Number

DICOM Tag	Description
0008,0054	Retrieve AE Title
0008,0061	Modalities in Study
0008,0080	Institution Name
0008,0090	Referring Physician's Name
0010,0010	Patient's Name
0010,0020	Patient ID
0010,0030	Patient's Birth Date
0010,0032	Patient's Birth Time
0010,0040	Patient's Sex
0008,1030	Study Description
0010,1020	Patient's Size
0010,1030	Patient's Weight
0008,1060	Name of Physician(s) Reading Study
0008,1070	Operator's Name
0020,000D	Study Instance UID
0020,0010	Study ID
0020,1206	Number Of Study Related Series
0020,1208	Number Of Study Related Images
Series level	
0004,1400	Offset Of The Next Dir Record
0004,1410	Record In Use Flag
0004,1420	Offset of Referenced Lower-Level Directory Entity
0004,1430	Directory Record Type
0004,1500	Referenced File ID
0008,0005	Specific Character Set
0008,0016	SOP Class UID
0008,0021	Series Date
0008,0023	Content Date
0008,0031	Series Time
0008,0033	Content Time
0008,0060	Modality
0008,0070	Manufacturer
0008,103E	Series Description
0018,0015	Body Part Examined
0018,1020	Software Version(s)
0018,1030	Protocol Name
0020,000E	Series Instance UID
0020,0011	Series Number
0020,1209	Number of Series Related Instances
0028,0008	Number of Frames
Image Level	
0004,1400	Offset Of The Next Dir Record
0004,1410	Record In Use Flag
0004,1420	Offset Of Ref Lower Level Dir Ent
0004,1430	Directory Record Type
	Referenced File ID
0004,1500	
0004,1510	Referenced Sop Class UID In File
0004,1511	Ref Sop Instance UID In File
0004,1512	Referenced Transfer Syntax UID in FILE

DICOM Tag	Description
0008,0005	Specific Character Set
0008,0008	Image Type
0018,0010	Contrast/Bolus Agent
0008,0016	SOP Class UID
0008,0018	SOP Instance UID
0008,0022	Acquisition Date
0008,0023	Content Date
0008,0032	Acquisition Time
0008,0033	Content Time
0018,0050	Slice Thickness
0018,0060	KVP
0020,0013	Instance Number
0020,0032	Image Position (Patient)
0020,1041	Slice Location
0020,4000	Image Comments
0020,0037	Image Orientation (Patient)
0020,0052	Frame of Reference UID
0028,0002	Samples per Pixels
0028,0004	Photometric Interpretation
0028,0008	Number of Frames
0028,0010	Rows
0028,0011	Columns
0028,0030	Pixel Spacing
0028,0100	Bits Allocated
0028,0101	Bits Stored
0028,0103	Pixel Representation

5.2.1.2.2.1.1. Options

Not applicable.

5.2.1.2.3. RWA - Display Directory

When a database open action is initiated on the CD/DVD then the Media AE acts as an FSR using the interchange option to read the DICOMDIR of the CD/DVD media.

This will result in an overview of the patients, studies, series and images on the Philips IntelliSpace Portal screen.

5.2.1.2.3.1. Media Storage Application Profile

The media AE supports the RWA Display Directory for the STD-CT/MR studies on CD, the STD-GEN-CD, the General Purpose DVD Interchange with JPEG and CT/MR Studies on DVD Media application profiles.

5.2.1.2.3.1.1. Options

The mandatory DICOMDIR keys are required for the correct display of directory information. The display is structured according the DICOM Composite Information Model: Patient, Study, Series, and Image.

The DICOM standard specifies certain attributes of the DICOMDIR as mandatory. However, these attributes may not be mandatory for the related SOP class IOD. For those attributes the default values apply.

5.3. Augmented and Private Application Profiles

Not applicable

5.4. Media Configuration

Not applicable.

6. Support of Character Sets

Any support for character sets in Network and Media services is described here.

Table 83: Supported DICOM Character Sets

Character Set Description	Defined Term	ESC Sequence	ISO Registration Number	Code Element	Character Set
Latin alphabet No. 1	ISO_IR 100	-	ISO-IR 6	G0	ISO 646
		-	ISO-IR 100	G1	Supplementary set of ISO 8859
Cyrillic	ISO_IR 144	-	ISO-IR 6	G0	ISO 646
		-	ISO-IR 144	G1	Supplementary set of ISO 8859
Default repertoire	-	-	ISO-IR 6	G0	ISO 646

7. Security

7.1. Security Profiles

Not applicable.

7.1.1. Security use Profiles

Not applicable

7.1.2. Security Transport Connection Profiles

Not applicable

7.1.3. Digital Signature Profiles

Not applicable

7.1.4. Media Storage Security Profiles

Not applicable

7.1.5. Attribute Confidentiality Profiles

No instances of the Encrypted Attributes Data Set are created. No Transfer Syntaxes are supported for encoding/decoding of Encrypted Attributes Data Sets.

The table below lists the protected attributes during the de-identification of patient data on export.

The terms used to describe the replacement value can be read as below:

- Empty: The attribute will have a value of zero length, is cleared by Philips IntelliSpace Portal.
- Copied: Attribute has same value as original.

Table 84: Basic Application Level Confidentiality Profile Attributes.

Attribute Name	Tag	VR	Replacement Value
Specific Character Set	0008,0005	CS	Copied from original
Accession Number	0008,0050	SH	[empty]
Institution Name	0008,0080	LO	Copied from original
Institution Address	0008,0081	ST	[empty] (according to selection in dialog)
Referring Physician's Name	0008,0090	PN	[empty]
Referring Physician's Address	0008,0092	ST	[empty]
Referring Physician's Telephone Numbers	0008,0094	SH	[empty]
Station Name	0008,1010	SH	[empty]
Study Description	0008,1030	SH	Copied from original
Series Description	0008,103E	LO	Copied from original
Institutional Department Name	0008,1040	LO	[empty]
Physician(s) of Record	0008,1048	PN	[empty]
Performing Physicians' Name	0008,1050	PN	[empty]
Name of Physician(s) Reading Study	0008,1060	PN	[empty]
Operators' Name	0008,1070	PN	[empty]
Admitting Diagnoses Description	0008,1080	LO	[empty]

Attribute Name	Tag	VR	Replacement Value	
Referenced Study Sequence	0008,1110	SQ	Copied from original	
Referenced Patient Sequence	0008,1120	SQ	[empty]	
Referenced SOP Instance UID	0008,1155	UI	[empty]	
Derivation Description	0008,2111	ST	[empty]	
Patient's Name	0010,0010	PN	[empty]	
Patient ID	0010,0020	LO	[empty]	
Issuer of Patient ID	0010,0021	LO	[empty]	
Patient's Birth Date	0010,0030	DA	[empty]	
Patient's Birth Time	0010,0032	TM	[empty]	
Patient's Sex	0010,0040	CS	Copied from original	
Other Patient ID's	0010,1000	LO	[empty]	
Other Patient Names	0010,1001	PN	[empty]	
Patient's Age	0010,1010	AS	If Patient's Birth Date exist calculated by Patient's Birth Date and Study Date	
			otherwise [empty]	
Patient's Size	0010,1020	DS	[empty]	
Patient Weight	0010,1030	DS	[empty]	
Patient's Address	0010,1040	LO	[empty]	
Medical Record Locator	0010,1090	LO	[empty]	
Medical Alerts	0010,2000	LO	[empty]	
Contrast Allergies	0010,2110	LO	[empty]	
Patient's Telephone Numbers	0010,2154	SH	[empty]	
Ethnic Group	0010,2160	SH	[empty]	
Occupation	0010,2180	SH	[empty]	
Additional Patient's History	0010,21B0	LT	[empty]	
Pregnancy Status	0010,21C0	US	[empty]	
Patient Comment	0010,4000	LT	[empty]	
Device Serial Number	0018,1000	LO	Copied from original	
Protocol Name	0018,1030	LO	Copied from original	
Study Instance UID	0020,000D	UI	New created UID	
Series Instance UID	0020,000E	UI	New created UID	
Study ID	0020,0010	SH	Copied from original	
Frame of Reference UID	0020,0052	UI	Copied from original	
Synchronization Frame of Reference UID	0020,0200	UI	Copied from original	
Image Comments	0020,4000	LT	Copied from original	
Requesting Physician	0032,1032	PN	[empty]	
Requesting Service	0032,1033	LO	Copied from original	
Requested Procedure Description	0032,1060	LO	Copied from original	
Requested Procedure Code Sequence	0032,1064	SQ	Copied from original	
Admission ID	0038,0010	LO	[empty]	
Special Needs	0038,0050	LO	[empty]	
Current Patient Location	0038,0300	LO	[empty]	
Patient State	0038,0500	LO	[empty]	
Scheduled Procedure Step Sequence	0040,0100	SQ	Copied from original	
Request Attributes Sequence	0040,0275	SQ	[empty]	
Requested Procedure ID	0040,1001	SH	Copied from original	
Names of Intended recipients of Results	0040,1010	PN	[empty]	
Requested Procedure Comments	0040,1400	LT	Copied from original	

Attribute Name	Tag	VR	Replacement Value
Imaging Service Request Comments	0040,2400	LT	Copied from original
Content Sequence	0040,A730	SQ	[empty]
Storage Media File Set UID	0088,0140	UI	[empty]
Referenced Frame of Reference UID	3006,0024	UI	Copied from original
Related Frame of Reference UID	3006,00C2	UI	Copied from original
[Private Attributes]	gggg,00bb (where gggg is odd)	nn	Copied from original

Note: Private DICOM attributes are defined freely by the creator of a DICOM object and may contain individually identifiable personal data. Private DICOM Attributes are neither modified nor deleted during the de-identification process on Philips IntelliSpace Portal.

7.1.6. Network Address Management Profiles

Not applicable

7.1.7. Time Synchronization Profiles

Not applicable

7.1.8. Application Configuration Management Profiles

Not applicable

7.1.9. Audit Trail Profiles

Not applicable

7.2. Association Level Security

Not applicable.

7.3. Application Level Security

System access is restricted by user accounts and requires a logon (username and password).

8. Clinical Applications

Following are the list of clinical applications available in Philips IntelliSpace Portal V5.0:

- CT Applications on Philips IntelliSpace Portal V5.0
- MR Applications on Philips IntelliSpace Portal V5.0
- Multi-Modality Applications on Philips IntelliSpace Portal V5.0
- IntelliSpace Collaboration Viewer on Philips IntelliSpace Portal V5.0
- NM Applications on Philips IntelliSpace Portal V5.0